

## **1.7 ACCREDITATION OF “VR” REPAIR ORGANIZATIONS**

### **1.7.1 SCOPE**

a) The administrative rules and procedures are provided by the National Board for those who wish to obtain a National Board Certificate of Authorization for use of the “VR” (Repair of Pressure Relief Valves) symbol stamp. It should be noted that the issuance of the “VR” stamp is not restricted to companies whose primary business is the repair of pressure relief valves, nor to manufacturers or assemblers that hold an ASME “V,” “HV,” “UV,” or “NV” Code symbol stamp. Owners and users of boilers and pressure vessels and other organizations that qualify in accordance with the National Board Rules and Regulations may also obtain the “VR” Certificate and stamp.

### **1.7.2 JURISDICTIONAL PARTICIPATION**

The National Board member jurisdiction in which the “VR” organization is located is encouraged to participate in the review and demonstration of the applicant’s quality system. The Jurisdiction may require participation in the review of the repair organization and the demonstration and acceptance of the repair organization’s quality system manual.

### **1.7.2 ISSUANCE AND RENEWAL OF THE “VR” CERTIFICATE OF AUTHORIZATION**

#### **1.7.2.1 GENERAL**

Authorization to use the stamp bearing the official National Board “VR” symbol as shown in Section 5 of this Part, will be granted by the National Board pursuant to the provisions of the following administrative rules and procedures

#### **1.7.2.2 ISSUANCE OF CERTIFICATE**

a) Repair organizations, manufacturers, assemblers, or users that make repairs to the American Society of Mechanical Engineers (ASME) Code symbol, stamped or marked (as applicable), and The National Board of Boiler and Pressure Vessel Inspectors (National Board) capacity certified pressure relief valves may apply to the National Board for a Certificate of Authorization to use the “VR” symbol.

### **1.7.3 USE OF THE “VR” AUTHORIZATION**

#### **1.7.3.1 TECHNICAL REQUIREMENTS**

The administrative requirements of 1.7 for use of the “VR” stamp shall be used in conjunction with the technical requirements for valve repair as described in Supplement 7 of the NBIC. Those requirements shall be mandatory when a “VR” repair is performed.

### **1.7.3.2 STAMP USE**

Each "VR" symbol stamp shall be used only by the repair firm within the scope, limitations, and restrictions under which it was issued.

### **1.7.4 QUALITY SYSTEM**

#### **1.7.4.1 GENERAL**

Each applicant for a new or renewed "VR" Certificate of Authorization shall have and maintain a quality system which shall establish that all of these rules and administrative procedures and applicable ASME Code requirements, including material control, fabrication, machining, welding, examination, setting, testing, inspection, sealing, and stamping will be met.

#### **1.7.4.2 WRITTEN DESCRIPTION**

A written description, in the English language, of the system the applicant will use shall be available for review and shall contain, as a minimum, the features set forth in 1.7.4.5. This description may be brief or voluminous, depending upon the projected scope of work, and shall be treated confidentially. In general, the quality system shall describe and explain what documents and procedures the repair firm will use to validate a valve repair.

#### **1.7.4.3 MAINTENANCE OF CONTROLLED COPY**

Each applicant to whom a "VR" Certificate of Authorization is issued shall maintain thereafter a controlled copy of the accepted quality system manual with the National Board. Except for changes that do not affect the quality system, revisions to the quality system manual shall not be implemented until such revisions are accepted by the National Board.

#### **1.7.4.4 OUTLINE OF REQUIREMENTS FOR A QUALITY SYSTEM**

The following establishes the minimum requirements of the written description of the quality system. It is required that each valve repair organization develop its own quality system that meets the requirements of its organization. For this reason it is not possible to develop one quality system that could apply to more than one organization. The written description shall include, as a minimum, the following features:

**a) Title Page**

The title page shall include the name and address of the company to which the National Board Certificate of Authorization is to be issued.

**b) Revision Log**

A revision log is required to assure revision control of the quality system manual. The log should contain sufficient space for date, description and section of revision, company approval, and National Board acceptance.

**c) Contents Page**

The contents page should list and reference, by paragraph and page number, the subjects and exhibits contained therein.

**d) Statement of Authority and Responsibility**

A statement of authority and responsibility shall be dated and signed by an officer of the company. It shall include:

1) A statement that the "VR" stamp shall be applied only to pressure relief valves that meet both of the following conditions:

a. Are stamped with an ASME "V", "UV", or "NV" Code symbol or marked with an ASME "HV" symbol and have been capacity certified by the National Board; and

b. Have been disassembled, inspected, and repaired by the Certificate Holder such that the valves' condition and performance are equivalent to the standards for new valves.

2) The title of the individual responsible to ensure that the quality system is followed and who has authority and freedom to effect the responsibility;

3) A statement that if there is a disagreement in the implementation of the written quality system, the matter is to be referred to a higher authority in the company for resolution; and

4) The title of the individual authorized to approve revisions to the written quality system and the method by which such revisions are to be submitted to the National Board for acceptance before implementation.

**e) Organization Chart**

A chart showing the relationship between management, purchasing, repairing, inspection, and quality control personnel is required and shall reflect the actual organization in place.

**f) Scope of Work**

1) The scope of work section shall indicate the scope and type of valve repairs, including conversions the organization is capable of

and intends to perform. The location of repairs (shop, shop and field, or field only), ASME Code Section(s) to which the repairs apply, the test medium (air, gas, liquid, or steam, or combinations thereof), and special processes (machining, welding, postweld heat treatment, or nondestructive examination, or combinations thereof) shall be specifically addressed.

2) The types and sizes of valves to be repaired, pressure ranges and other limitations, such as engineering and test facilities, should also be addressed.

#### **g) Drawings and Specification Control**

The drawings and specification control system shall provide procedures assuring that the latest applicable drawings, specifications, and instructions required are used for valve repair, including conversions, inspection, and testing.

#### **h) Material and Part Control**

The material and part control section shall describe purchasing, receiving, storage, and issuing of parts.

1) State the title of the individual responsible for the purchasing of all material.

2) State the title of the individual responsible for certification and other records as required.

3) All incoming material and parts shall be checked for conformance with the purchase order and, where applicable, the material specifications or drawings. Indicate how material or part is identified and how identity is maintained by the quality system.

#### **i) Repair and Inspection Program**

The repair and inspection program section shall include reference to a document (such as a report, traveler, or checklist) that outlines the specific repair and inspection procedures used in the repair of pressure relief valves. Repair procedures shall require verification that the critical parts meet the valve manufacturer's specification. Supplement S7.14 outlines recommended procedures covering some specific items. Provisions shall be made to retain this document for a period of at least five years.

1) Each valve or group of valves shall be accompanied by the document referred to above for processing through the plant. Each valve shall have a unique identifier (i.e., repair serial number, shop order number, etc.) appearing on the repair documentation and repair nameplate such that traceability is established.

2) The document referred to above shall describe the original nameplate information, including the ASME Code symbol stamping and the repair nameplate information, if applicable. In addition, it shall include material checks, replacement parts, conversion parts (or both), reference to items such as the welding procedure specifications (WPS), fitup, NDE technique, heat treatment, and pressure test methods to be used. Application of the "VR" stamp to the repair nameplate shall be recorded in this document. Specific conversions performed with the new Type/Model number shall be recorded on the document. There shall be a space for "signoffs" at each operation to verify that each step has been properly performed.

3) The system shall include a method of controlling the repair or replacement of critical valve parts. The method of identifying each spring shall be indicated.

4) The system shall also describe the controls used to ensure that any personnel engaged in the repair of pressure relief valves are trained and qualified in accordance with Supplement S7.

**j) Welding, NDE, and Heat Treatment (when applicable)**

The quality system manual shall indicate the title of the person(s) responsible for and describe the system used in the selection, development, approval, and qualification of welding procedure specifications, and the qualification of welders and welding operators in accordance with the provisions of S7.

1) The quality system manual may include controls for the "VR" Certificate Holder to have the pressure relief valve part repaired by a National Board "R" Certificate Holder, per Supplement S7.

2) The completed Form R-1 shall be noted on and attached to the "VR" Certificate Holder's document required in 1.7.4.5(i). Similarly, NDE and heat treatment techniques must be covered in the quality system manual. When outside services are used for NDE and heat treatment, the quality system manual shall describe the system whereby the use of such services meet the requirements of the applicable section of the ASME Code.

### **k) Valve Testing, Setting, and Sealing**

The system shall include provisions that each valve shall be tested, set, and all external adjustments sealed according to the requirements of the applicable ASME Code Section and the National Board. The seal shall identify the "VR" Certificate Holder making the repair. Abbreviations or initials shall be permitted, provided such identification is acceptable to the National Board.

### **l) Valve Repair Nameplates**

An effective valve stamping system shall be established to ensure proper stamping of each valve as required by 5.9.2. The manual shall include a description of the nameplate or a drawing.

### **m) Calibration**

1) The manual shall describe a system for the calibration of examination, measuring, and test equipment used in the performance of repairs. Documentation of these calibrations shall include the standard used and the results.

2) All calibration standards shall be calibrated against certified equipment having known valid relationships to nationally recognized standards.

### **n) Manual Control**

The quality system shall include:

1) Measures to control the issuance of and revisions to the quality system manual;

2) Provisions for a review of the system in order to maintain the manual current with these rules and the applicable sections of the ASME Code;

3) The title(s) of the individual(s) responsible for control, revisions, and review of the manual;

4) Provision of a controlled copy of the written quality system manual to be submitted to the National Board; and

5) Revisions shall be submitted for acceptance by the National Board prior to being implemented.

### **o) Nonconformities**

The system shall establish measures for the identification, documentation, evaluation, segregation, and disposition of nonconformities. A nonconformity is a condition of any material, item, product, or process in which one or more characteristics do not conform to the established requirements. These may include, but are not limited to, data discrepancies, procedural and/or documentation deficiencies, or material defects. Also, the title(s) of the individual(s) involved in this process shall be included.

**p) Exhibits**

Forms used in the quality system shall be included in the manual with a written description. Forms exhibited should be marked SAMPLE and completed in a manner typical of actual valve repair procedures.

**q) Testing Equipment (See Supplement 8)**

The system shall include a means to control the development, addition, or modification of testing equipment to ensure the requirements of 4.5.1(b) are met.

**r) Field Repairs (See Supplement S7.7)**

If field repairs are included in the scope of work, the system shall address any differences or additions to the quality system required to properly control this activity, including the following:

- 1) Provisions for annual audits of field activities shall be included;
- 2) Provisions for receipt and inspection of replacement parts, including parts received from the owner-user, shall be addressed;
- 3) If owner-user personnel will assist with repairs, provisions for the use of owner-user personnel shall be included; and
- 4) Provisions for use of owner-user measurement and test equipment, if applicable, shall be addressed.

## 1.8 "NR" ACCREDITATION REQUIREMENTS

### 1.8.1 SCOPE

a) ~~This section provides~~ The requirements that must to be met for an organization to obtain a National Board Certificate of Authorization to use the "NR" Symbol Stamp for the Repair/Replacement activities performed in accordance with this Part and ASME Section XI requirements.

b) The issuance of the "NR" stamp is not restricted to organizations whose primary business is to perform repair/replacement activities or to manufacturers or assemblers that hold an ASME "N"-type Code symbol stamp. Owners and users of nuclear components and other organizations that qualify in accordance with these rules may also obtain the "NR" stamp may be obtained from the National Board.

### ~~1.8.2 PREREQUISITES FOR ISSUING A NATIONAL BOARD "NR" CERTIFICATE OF AUTHORIZATION~~

~~Before an organization can obtain a National Board "NR" Certificate of Authorization, the organization shall:~~

~~a) Have and maintain an inspection agreement with an accredited Nuclear Inspection Agency in accordance with NB-360<sup>4</sup>, NB-369<sup>5</sup>, and ASME Section XI;~~

~~b) Have in the English language a written Quality System Program that complies with the requirements of this Section and addresses controls for the intended scope of activities;~~

~~c) Have a current edition and addenda of the NBIC, all parts; and~~

~~d) Have available copies of the original code of construction appropriate to the intended scope of work and the applicable edition and addenda of ASME Section XI, as required by the regulatory authority.<sup>6</sup>~~

### ~~1.8.3 PROCEDURES FOR OBTAINING OR RENEWING A NATIONAL BOARD "NR" CERTIFICATE OF AUTHORIZATION~~

~~a) Prior to issuance or renewal of a National Board "NR" Certificate of Authorization, the organization and its facilities are subject to a review of its Quality System Program. The implementation of the Quality System Program shall be satisfactorily demonstrated by the organization. Demonstration of implementation shall meet the most stringent code requirements for the scope of work to be performed by the organization. The National Board reserves the absolute right to cancel, refuse to issue,~~

### **1.8.2 1.8.4 NATIONAL BOARD "NR" SYMBOL STAMP**

a) All "NR" Symbol Stamps shall be obtained from the National Board of Boiler and Pressure Vessel Inspectors. Authorization to use the "NR" Symbol Stamp may be granted by the National Board at its absolute discretion.

~~b) The National Board, for a nominal fee, furnishes the "NR" Symbol Stamp. Each organization shall agree, if authorized to use the "NR" Symbol Stamp, that the "NR" Symbol Stamp is at all times the property of the National Board and will be promptly returned upon demand. If the organization discontinues the use of the "NR" Symbol Stamp or if the Certificate of Authorization has expired and no new Certificate of Authorization has been issued, the "NR" Symbol Stamp shall be returned to the National Board.~~

~~e) The organization's Quality System Program shall provide for adequate control of the "NR" Symbol Stamp.~~

~~d) The organization authorized to use the "NR" Symbol Stamp may obtain more than one "NR" Symbol Stamp provided the organization's Quality System Program describes how the use of such stamps are controlled from the location shown on the "NR" Certificate of Authorization.~~

~~b) e) The organization shall not permit other organizations to use the "NR" Symbol Stamp loaned to it by the National Board.~~

### **1.8.3 1.8.5 QUALITY SYSTEM PROGRAM**

A holder of a National Board Certificate of Authorization shall have and maintain a written Quality System Program. The system shall satisfactorily meet the requirements of the NBIC, jurisdictional requirements, and shall be available for review. The Quality System Program may be brief or voluminous, depending on the circumstances. It shall be treated confidentially by the National Board.

#### **1.8.3.1 1.8.5.1 OUTLINE OF REQUIREMENTS FOR A QUALITY SYSTEM PROGRAM FOR QUALIFICATION FOR THE NATIONAL BOARD "NR" SYMBOL STAMP**

These rules set forth the requirements for planning, managing, and implementing the organization's Quality System Programs for controlling the quality of activities performed during repair/replacement activities of components and systems in nuclear power plants within the scope of the applicable edition and addenda of Section XI of the ASME Code. These

rules are to be the basis for evaluating such programs prior to the issuance of the National Board "NR" Certificate of Authorization.

**a) Organization**

1) The authority and responsibility of those in charge of the Quality System Program and activities affecting quality shall be clearly established and documented. The person and organization performing Quality System functions shall have sufficient and well-defined responsibility, authority, and organizational freedom to:

- a. Identify quality problems;
- b. Initiate action which results in solutions;
- c. Verify implementation of solutions to those problems; and
- d. Control further processing, delivery or installation of a nonconforming item, deficiency or unsatisfactory condition until proper disposition has been made.

2) The person and organization responsible for defining and for measuring the overall effectiveness of the Quality System Program shall be designated sufficiently independent from the pressure of production, have direct access to responsible management at a level where appropriate action can be required and report regularly on the effectiveness of the program. Assurance of quality requires management measures which provide that the individual or group assigned the responsibility of inspection, testing, checking, or otherwise verifying that an activity has been correctly performed, is independent of the individual or group directly responsible for performing the specific activity. The specific responsibilities of the Quality Assurance organization of the "NR" Certificate Holder shall include the review of written procedures and monitoring of all activities concerned with the Quality System Program as covered in these rules.

**b) Quality System Program**

1) Before becoming a holder of an "NR" Certificate of Authorization, the applicant shall establish a Quality System Program for the control of the quality of work to be performed. The program shall define the organizational structure within which the Quality System Program is to be implemented and shall clearly delineate the responsibilities, levels of authority, and lines of communication for the various individuals involved. The program shall be documented in detail in a Quality System Manual that shall be a major basis for

demonstration of compliance with the NBIC. The applicant's Quality System Program shall be documented by written policies, procedures, and instructions and shall be based on the organization's scope of work to be performed.

2) The applicant's program need not be in the same format or sequential arrangement as the requirements in these rules as long as all applicable program requirements have been covered. The program shall provide for the accomplishment of activities affecting quality under suitably controlled conditions. Controlled conditions include the use of appropriate equipment, suitable environmental conditions for accomplishing the activity and assurance that prerequisites for the activity have been satisfied. The program shall take into account the need for special controls, processes, test equipment, tools, and skills to attain the required quality and need for the verification of quality by inspection and test. The program shall provide for ready detection of nonconforming material and items and for timely and positive corrective actions.

3) The program shall provide for indoctrination and training of personnel performing activities affecting quality as necessary to assure that suitable proficiency is achieved and maintained. It shall be the responsibility of the "NR" Certificate Holder to ensure that all personnel performing quality functions within the scope of these rules, including personnel of subcontracted services, are qualified as specified in these rules. The assignment of qualified personnel shall be at the discretion of the "NR" certificate holder.

4) The "NR" Certificate Holder shall be responsible for advising his Authorized Nuclear Inspection Agency of any proposed changes to the Quality System Manual and shall have acceptance of the Authorized Nuclear Inspection Agency's Authorized Nuclear Inspector Supervisor before putting such changes into effect. The "NR" Certificate Holder shall make a current copy of the Quality System Manual available to the Authorized Nuclear Inspector. The "NR" Certificate Holder shall be responsible for promptly notifying the Authorized Nuclear Inspector of such accepted changes, including evidence of acceptance by the Authorized Nuclear Inspection Agency.

5) The quality of all repair/replacement activities shall be controlled at all points necessary to ensure conformance with the requirements of these rules and the "NR" Certificate Holder's Quality System Manual.

6) The Certificate Holder shall make available to the Authorized Nuclear Inspector such drawings and process sheets as are necessary to make the Quality System Program intelligible.

**c) Design Control**

1) ASME Section XI establishes that the owner is responsible for design in connection with repair/replacement activities. The "NR" Certificate Holder must ensure that the design specification, drawings, or other specifications or instructions furnished by the owner satisfy the code edition and addenda of the owner's design specification. To satisfy this requirement, the "NR" Certificate Holder shall establish requirements that correctly incorporate the owner's design specification requirements into their specifications, drawings, procedures, and instructions, which may be necessary to carry out the work. The "NR" Certificate Holder's system shall include provisions to ensure that the appropriate quality standards are specified and included in all quality records. These records shall be reviewed for compliance with the owner's design specification and the requirements of Section XI of the ASME Boiler and Pressure Vessel Code.

2) If the "NR" Certificate Holder's specifications, drawings, procedures, and instructions conflict with the owner's design specification, a system must be implemented that will resolve or eliminate the deficiency. This system must be reconciled with the owner and the "NR" Certificate Holder in accordance with IWA-4000 of Section XI of the ASME Code.

**d) Procurement Document Control**

Documents for procurement of materials, items, and subcontracted services shall include requirements to the extent necessary to ensure their compliance with the owner's design specifications and IWA-4000 of Section XI of the ASME Code. To the extent necessary, procurement documents shall require suppliers to maintain a Quality System Program consistent with the applicable requirements of the edition and addenda of the code of construction to which the items are constructed. Measures shall be established

to ensure that all purchased material, items, and services conform to these requirements.

**e) Instructions, Procedures and Drawings**

Activities affecting quality shall be prescribed by documented instructions, procedures or drawings of a type appropriate to the circumstances and shall be accomplished in accordance with these instructions, procedures, or drawings. Instructions, procedures, or drawings shall include appropriate quantitative and qualitative criteria for determining that activities affecting quality have been satisfactorily accomplished. The "NR" Certificate Holder shall maintain a written description of procedures, instructions, or drawings used by his organization for control of quality and examination requirements detailing the implementation of the Quality System requirements. Copies of these procedures shall be readily available to the Authorized Nuclear Inspector.

**f) Document Control**

The program shall include measures to control the issuance, use, and disposition of documents, such as specifications, instructions, procedures, and drawings, including changes thereto. These measures shall ensure that the latest applicable documents, including changes, are reviewed for adequacy and approved for release by authorized personnel and distributed for use at the location where the prescribed activity is performed.

**g) Control of Purchased Material, Items, and Services**

Measures shall be established to ensure that all purchased material, items, and services conform to the requirements of the owner's design specifications and applicable edition and addenda of the code of construction and Section XI of the ASME Code. These measures shall include identification for material traceability. Provisions shall be identified for source evaluation and objective evidence shall be provided evidencing quality standards for material examination upon receipt.

**h) Identification and Control of Material and Items**

1) Measures shall be established for identification and control of material and items, including partially fabricated assemblies. These measures shall ensure that identification is maintained and traceable, either on the material or component, or on records throughout the repair/replacement activity. These measures shall be designed to prevent the

use of incorrect or defective items and those which have not received the required examinations, tests, or inspections.

2) Permanent or temporary unit identification marks shall be applied using methods and materials that are legible and not detrimental to the component or system involved. Such identification shall be located in areas that will not interfere with the function or quality aspects of the item.

3) Certified Material Test Reports shall be identified as required by the applicable material specification in Section II of the ASME Code and shall satisfy any additional requirements specified in the original code of construction. The Certified Material Test Report or Certificate of Compliance need not be duplicated for submission with compliance documents when a record of compliance and satisfactory reviews of the Certified Material Test Report and Certificates of Compliance is provided. Documents shall provide a record that the Certified Material Test Report and Certificates of Compliance have been received, reviewed, and found acceptable. When the "NR" Certificate Holder Scope authorizes the organization to perform examinations and tests in accordance with the original code of construction, the "NR" Certificate Holder shall certify compliance either on a Certified Material Test Report or Certificate of Conformance that the material satisfies the original code of construction requirements.

#### **i) Control of Processes**

1) The "NR" Certificate Holder shall operate under a controlled system such as process sheets, checklists, travelers, or equivalent procedures. Measures shall be established to assure that processes such as welding, nondestructive examination, and heat treating are controlled in accordance with the rules of the applicable section of the ASME Code and are accomplished by qualified personnel using qualified procedures.

2) Process sheets, checklists, travelers, or equivalent documentation shall be prepared, including the document numbers and revisions to which the process conforms with space provided for reporting results of completion of specific operations at checkpoints of repair/replacement activities.

#### **j) Examinations, Tests and Inspections**

1) In-process and final examinations and tests shall be established to assure conformance with specifications, drawings, instructions, and procedures which incorporate or reference the requirements and acceptance limits contained in applicable design documents. Examination activities to verify the quality of work shall be performed by persons other than those who performed the activity being examined. Such persons shall not report directly to the immediate supervisors responsible for the work being examined.

2) Process sheets, travelers, or checklists shall be prepared, including the document numbers and revision to which the examination or test is to be performed, with space provided for recording results.

3) Mandatory hold/inspection points at which witnessing is required by the "NR" Certificate Holder's representative or the Authorized Nuclear Inspector shall be indicated in the controlling documents. Work shall not proceed beyond mandatory hold/inspection points without the consent of the "NR" Certificate Holder's representative or the Authorized Nuclear Inspector, as appropriate.

#### **k) Test Control**

1) Testing shall be performed in accordance with the owner's written test procedures that incorporate or reference the requirements and acceptance limits contained in applicable design documents.

2) Test procedures shall include provisions for assuring that prerequisites for the given test have been met, that adequate instrumentation is available and used, and that necessary monitoring is performed. Prerequisites may include calibrated instrumentation, appropriate equipment, trained personnel, condition of test equipment and the item to be tested, suitable environmental conditions, and provisions for data acquisition.

3) Test results shall be documented and evaluated to assure that test requirements have been satisfied.

#### **l) Control of Measuring and Test Equipment**

Measures shall be established and documented to assure that tools, gages,

instruments, and other measuring and testing equipment and devices used in activities affecting quality are of the proper range, type, and accuracy to verify conformance to established requirements. A procedure shall be in effect to assure that they are calibrated and properly adjusted at specified periods or use intervals to maintain accuracy within specified limits. Calibration shall be traceable to known national standards, where these standards exist, or with the device manufacturer's recommendation.

m) Quality Records

1) The owner is responsible for designating records to be maintained. Measures shall be established for the "NR" Certificate Holder to maintain these records [See 1.8.5.1(m)(2)] required for Quality Assurance of repair/replacement activities. These shall include documents such as records of materials, manufacturing, examination, and test data taken before and during repair/replacement activity. Procedures, specifications, and drawings used shall be fully identified by pertinent material or item identification numbers, revision numbers, and issue dates. The records shall also include related data such as qualification of personnel, procedures, equipment, and related repairs. The "NR" Certificate Holder shall take such steps as may be required to provide suitable protection from deterioration and damage for all records while in his care. Also, it is required that the "NR" Certificate Holder have a system for correction or amending records that satisfies the owner's requirements. These records may be either the original or a reproduced, legible copy and shall be transferred to the owner at his request.

2) Records to be maintained as required in 1.8.5.1(m)(1) above may include the following:

- a. An index that details the location and who is responsible for maintaining the records;
- b. Data reports, properly executed, for each replacement component, part, appurtenance, piping system, and piping assembly, when required by the design specification or the owner;
- c. The required as-constructed drawings certified as to correctness;
- d. Copies of applicable Certified Material Test Reports and Certificates of Compliance;

e. As-built sketch(es) including tabulations of materials repair/replacement procedures, and instructions to achieve compliance with Section XI of the ASME Code;

f. Nondestructive examination reports including results of examinations shall identify the ASNT, SNT-TC-1A, CP-189, or ACCP level of personnel interpreting the examination results. The ASNT Central Certification Program (ACCP) may be used to fulfill the examination and demonstration requirement of the employer's written practice. Final radiographs shall be included where radiography has been performed;

g. Records of all heat treatments may be either the heat treatment charts or a summary description of heat treatment time and temperature data certified by the "NR" Certificate Holder. Heat treatments performed by the material manufacturer to satisfy requirements of the material specifications may be reported on the Certified Material Test Report; or

h. Any and all nonconformance reports shall satisfy IWA-4000 of Section XI of the ASME Code and shall be reconciled by the owner prior to certification of the Form NR-1 or NVR-1, as applicable.

3) After a repair/replacement activity, all records including audit reports required to verify compliance with the applicable engineering documents and the "NR" Certificate Holder's Quality System Program, except those required by the owner or listed in 1.8.5.1(m)(2)(a) thru (g) above, shall be maintained at a place mutually agreed upon by the owner and the "NR" Certificate Holder. These records shall be maintained for a period of five years after completion of the repair/replacement activity.

4) The original of the completed Form NR-1 or Form NVR-1, as applicable, shall be registered with the National Board and, if required, a copy forwarded to the Jurisdiction where the nuclear power plant is located.

**n) Examination or Test Status**

Measures shall be established to indicate examination and test status of parts, items, or components during the repair/replacement activity. The system used shall provide positive identification of the part, item, or component by means of stamps, labels, routing cards, or other acceptable methods. The system shall include any procedures or instructions to achieve compliance. Also, measures shall be provided for the identification of acceptable and unacceptable items. They shall also include procedures for control of status indicators, including the authority for application and removal of status indicators.

**o) Nonconforming Materials or Items**

Measures shall be established to control materials or items that do not conform to requirements in order to prevent their inadvertent use, including measures to identify and control the proper installation of items and to preclude nonconformance with the requirements of these rules. These measures shall include procedures for identification, documentation, segregation, and disposition. Nonconforming items shall be reviewed for acceptance, rejection, or repair in accordance with documented procedures. The responsibility and authority for the disposition of nonconforming items shall be defined. Repaired or modified items shall be re-examined in accordance with the applicable procedures. Measures that control further processing of a nonconforming or defective item, pending a decision on its disposition, shall be established and maintained. Ultimate disposition of nonconforming items shall be documented.

**p) Corrective Action**

- 1) Measures shall be established to ensure that conditions adverse to quality such as failures, malfunctions, deficiencies, deviations, defective material and equipment, and other nonconformances are promptly identified and corrected.
- 2) In the case of significant conditions adverse to quality, the measures shall also ensure that the cause of these conditions be determined and corrected to preclude repetition. The identification of significant conditions adverse to quality, the cause, and condition and the corrective action taken shall be documented and reported to the appropriate levels of management.
- 3) The requirements shall also extend to the performance of subcontractors' corrective action measures.

**q) Audits**

A comprehensive system of planned and periodic audits shall be carried out by the "NR" Certificate Holder's organization to ensure compliance with the Quality System Program and to determine its effectiveness. Audits shall be performed in accordance with written procedures or checklists by personnel not having direct responsibilities in the areas being audited. Audit results shall be documented by the auditing personnel for review by management having responsibility in that area. Follow-up action, including re-audit of deficient areas, shall be taken where indicated. Audit results shall be made available to the Authorized Nuclear Inspector.

**r) Authorized Nuclear Inspector**

Measures shall be taken to reference the commissioned Rules for National Board Authorized Nuclear Inspector, qualified in accordance with the Rules for National Board Inservice and New Construction Commissioned Inspectors, to ensure that the latest documents including the Quality System Program will be made available to the inspector. The Authorized Nuclear Inspector shall be consulted prior to the issuance of a repair/replacement program in order that the Inspector may select any inspection or hold points in the program. The Authorized Nuclear Inspector shall not sign Form NR-1 or Form NVR-1, as applicable, unless satisfied that all work carried out is in accordance with the NBIC, ASME Section XI, and any jurisdictional requirements.

**s) Exhibits**

Forms referenced in the Quality System Manual shall be explained in the text and included as part of the referencing document or as an appendix. Forms shall be controlled and identified to show the latest approved revision, exhibit name, and other corresponding references as stated in the Quality System manual.

**1.8.6 INTERFACE WITH THE OWNER'S REPAIR/REPLACEMENT PROGRAM**

~~Interface with the owner's repair/replacement program shall meet the following:~~

- ~~a) The repair/replacement plan shall be subject to the acceptance of the Jurisdiction and the owner's Authorized Nuclear In-service Inspector (ANII).~~

~~b) Repair/replacement activities of nuclear components shall meet the requirements of Section XI of the ASME Boiler and Pressure Vessel Code and the Jurisdiction where the nuclear power plant is located.~~

~~c) Documentation of the repair/replacement activities of nuclear components shall be recorded on the National Board Report of Nuclear Repair/Modification or Replacement activities, Form NR-1, or Form NVR-1, as applicable. The completed forms shall be signed by a representative of the authorized nuclear repair organization and the Authorized Nuclear Inspector if the repair/replacement activity meets the requirements of ASME Section XI. For repair/replacement activities that involve design changes as specified in 1.8.5.1(c), Form NR-1, or Form NVR-1, as applicable, shall indicate the responsible organization satisfying the owner's design specification requirements.~~

~~d) The authorized nuclear repair organization shall provide a copy of the signed Form NR-1 or Form NVR-1, as applicable, to the owner, if required, the Jurisdiction, and the Authorized Nuclear Inspection Agency. The original Form NR-1 or Form NVR-1, as applicable, shall be registered with the National Board by the authorized nuclear repair organization.~~

~~e) The authorized nuclear repair organization shall provide a nameplate/stamping for repair/replacement activities for each nuclear component unless otherwise required by the Owner's Quality System Program. The required information and format shall be as shown in Section 5 of this Part.~~

## **1.8 “NR” ACCREDITATION REQUIREMENTS**

### **1.8.1 SCOPE**

a) The requirements to be met for an organization to obtain a National Board Certificate of Authorization to use the “NR” Symbol Stamp for the Repair/Replacement activities performed in accordance with this Part and ASME Section XI requirements.

b) The issuance of the “NR” stamp is not restricted to organizations whose primary business is to perform repair/replacement activities or to manufacturers or assemblers that hold an ASME “N”-type Code symbol stamp. Owners and users of nuclear components and other organizations that qualify in accordance with these rules may also obtain the “NR” stamp may be obtained from the National Board.

### **1.8.2 NATIONAL BOARD “NR” SYMBOL STAMP**

a) All “NR” Symbol Stamps shall be obtained from the National Board of Boiler and Pressure Vessel Inspectors. Authorization to use the “NR” Symbol Stamp may be granted by the National Board at its absolute discretion.

b) The organization shall not permit other organizations to use the “NR” Symbol Stamp loaned to it by the National Board.

### **1.8.3 QUALITY SYSTEM PROGRAM**

A holder of a National Board Certificate of Authorization shall have and maintain a written Quality System Program. The system shall satisfactorily meet the requirements of the NBIC, jurisdictional requirements, and shall be available for review. The Quality System Program may be brief or voluminous, depending on the circumstances. It shall be treated confidentially by the National Board.

#### **1.8.3.1 OUTLINE OF REQUIREMENTS FOR A QUALITY SYSTEM PROGRAM FOR QUALIFICATION FOR THE NATIONAL BOARD “NR” SYMBOL STAMP**

These rules set forth the requirements for planning, managing, and implementing the organization’s Quality System Programs for controlling the quality of activities performed during repair/replacement activities of components and systems in nuclear power plants within the scope of the applicable edition and addenda of Section XI of the ASME Code. These rules are to be the basis for evaluating such programs prior to the issuance of the National Board “NR” Certificate of Authorization.

## **a) Organization**

1) The authority and responsibility of those in charge of the Quality System Program and activities affecting quality shall be clearly established and documented. The person and organization performing Quality System functions shall have sufficient and well-defined responsibility, authority, and organizational freedom to:

- a. Identify quality problems;
- b. Initiate action which results in solutions;
- c. Verify implementation of solutions to those problems; and
- d. Control further processing, delivery or installation of a nonconforming item, deficiency or unsatisfactory condition until proper disposition has been made.

2) The person and organization responsible for defining and for measuring the overall effectiveness of the Quality System Program shall be designated sufficiently independent from the pressure of production, have direct access to responsible management at a level where appropriate action can be required and report regularly on the effectiveness of the program. Assurance of quality requires management measures which provide that the individual or group assigned the responsibility of inspection, testing, checking, or otherwise verifying that an activity has been correctly performed, is independent of the individual or group directly responsible for performing the specific activity. The specific responsibilities of the Quality Assurance organization of the "NR" Certificate Holder shall include the review of written procedures and monitoring of all activities concerned with the Quality System Program as covered in these rules.

## **b) Quality System Program**

1) Before becoming a holder of an "NR" Certificate of Authorization, the applicant shall establish a Quality System Program for the control of the quality of work to be performed. The program shall define the organizational structure within which the Quality System Program is to be implemented and shall clearly delineate the responsibilities, levels of authority, and lines of communication for the various individuals involved. The program shall be documented in detail in a Quality System Manual that shall be a major basis for demonstration of compliance with the NBIC. The applicant's Quality System Program shall be documented by written policies,

procedures, and instructions and shall be based on the organization's scope of work to be performed.

2) The applicant's program need not be in the same format or sequential arrangement as the requirements in these rules as long as all applicable program requirements have been covered. The program shall provide for the accomplishment of activities affecting quality under suitably controlled conditions. Controlled conditions include the use of appropriate equipment, suitable environmental conditions for accomplishing the activity and assurance that prerequisites for the activity have been satisfied. The program shall take into account the need for special controls, processes, test equipment, tools, and skills to attain the required quality and need for the verification of quality by inspection and test. The program shall provide for ready detection of nonconforming material and items and for timely and positive corrective actions.

3) The program shall provide for indoctrination and training of personnel performing activities affecting quality as necessary to assure that suitable proficiency is achieved and maintained. It shall be the responsibility of the "NR" Certificate Holder to ensure that all personnel performing quality functions within the scope of these rules, including personnel of subcontracted services, are qualified as specified in these rules. The assignment of qualified personnel shall be at the discretion of the "NR" certificate holder.

4) The "NR" Certificate Holder shall be responsible for advising his Authorized Nuclear Inspection Agency of any proposed changes to the Quality System Manual and shall have acceptance of the Authorized Nuclear Inspection Agency's Authorized Nuclear Inspector Supervisor before putting such changes into effect. The "NR" Certificate Holder shall make a current copy of the Quality System Manual available to the Authorized Nuclear Inspector. The "NR" Certificate Holder shall be responsible for promptly notifying the Authorized Nuclear Inspector of such accepted changes, including evidence of acceptance by the Authorized Nuclear Inspection Agency.

5) The quality of all repair/replacement activities shall be controlled at all points necessary to ensure conformance

with the requirements of these rules and the "NR" Certificate Holder's Quality System Manual.

6) The Certificate Holder shall make available to the Authorized Nuclear Inspector such drawings and process sheets as are necessary to make the Quality System Program intelligible.

**c) Design Control**

1) ASME Section XI establishes that the owner is responsible for design in connection with repair/replacement activities. The "NR" Certificate Holder must ensure that the design specification, drawings, or other specifications or instructions furnished by the owner satisfy the code edition and addenda of the owner's design specification. To satisfy this requirement, the "NR" Certificate Holder shall establish requirements that correctly incorporate the owner's design specification requirements into their specifications, drawings, procedures, and instructions, which may be necessary to carry out the work. The "NR" Certificate Holder's system shall include provisions to ensure that the appropriate quality standards are specified and included in all quality records. These records shall be reviewed for compliance with the owner's design specification and the requirements of Section XI of the ASME Boiler and Pressure Vessel Code.

2) If the "NR" Certificate Holder's specifications, drawings, procedures, and instructions conflict with the owner's design specification, a system must be implemented that will resolve or eliminate the deficiency. This system must be reconciled with the owner and the "NR" Certificate Holder in accordance with IWA-4000 of Section XI of the ASME Code.

**d) Procurement Document Control**

Documents for procurement of materials, items, and subcontracted services shall include requirements to the extent necessary to ensure their compliance with the owner's design specifications and IWA-4000 of Section XI of the ASME Code. To the extent necessary, procurement documents shall require suppliers to maintain a Quality System Program consistent with the applicable requirements of the edition and addenda of the code of construction to which the items are constructed. Measures shall be established to ensure that all purchased material, items, and services conform to these requirements.

#### **e) Instructions, Procedures and Drawings**

Activities affecting quality shall be prescribed by documented instructions, procedures or drawings of a type appropriate to the circumstances and shall be accomplished in accordance with these instructions, procedures, or drawings. Instructions, procedures, or drawings shall include appropriate quantitative and qualitative criteria for determining that activities affecting quality have been satisfactorily accomplished. The "NR" Certificate Holder shall maintain a written description of procedures, instructions, or drawings used by his organization for control of quality and examination requirements detailing the implementation of the Quality System requirements. Copies of these procedures shall be readily available to the Authorized Nuclear Inspector.

#### **f) Document Control**

The program shall include measures to control the issuance, use, and disposition of documents, such as specifications, instructions, procedures, and drawings, including changes thereto. These measures shall ensure that the latest applicable documents, including changes, are reviewed for adequacy and approved for release by authorized personnel and distributed for use at the location where the prescribed activity is performed.

#### **g) Control of Purchased Material, Items, and Services**

Measures shall be established to ensure that all purchased material, items, and services conform to the requirements of the owner's design specifications and applicable edition and addenda of the code of construction and Section XI of the ASME Code. These measures shall include identification for material traceability. Provisions shall be identified for source evaluation and objective evidence shall be provided evidencing quality standards for material examination upon receipt.

#### **h) Identification and Control of Material and Items**

1) Measures shall be established for identification and control of material and items, including partially fabricated assemblies. These measures shall ensure that identification is maintained and traceable, either on the material or component, or on records throughout the repair/replacement activity. These measures shall be designed to prevent the use of incorrect or defective items and those which have not received the required examinations, tests, or inspections.

2) Permanent or temporary unit identification marks shall be applied using methods and materials that are legible and not detrimental to the component or system involved. Such identification shall be located in areas that will not interfere with the function or quality aspects of the item.

3) Certified Material Test Reports shall be identified as required by the applicable material specification in Section II of the ASME Code and shall satisfy any additional requirements specified in the original code of construction. The Certified Material Test Report or Certificate of Compliance need not be duplicated for submission with compliance documents when a record of compliance and satisfactory reviews of the Certified Material Test Report and Certificates of Compliance is provided. Documents shall provide a record that the Certified Material Test Report and Certificates of Compliance have been received, reviewed, and found acceptable. When the "NR" Certificate Holder Scope authorizes the organization to perform examinations and tests in accordance with the original code of construction, the "NR" Certificate Holder shall certify compliance either on a Certified Material Test Report or Certificate of Conformance that the material satisfies the original code of construction requirements.

#### **i) Control of Processes**

1) The "NR" Certificate Holder shall operate under a controlled system such as process sheets, checklists, travelers, or equivalent procedures. Measures shall be established to assure that processes such as welding, nondestructive examination, and heat treating are controlled in accordance with the rules of the applicable section of the ASME Code and are accomplished by qualified personnel using qualified procedures.

2) Process sheets, checklists, travelers, or equivalent documentation shall be prepared, including the document numbers and revisions to which the process conforms with space provided for reporting results of completion of specific operations at checkpoints of repair/replacement activities.

#### **j) Examinations, Tests and Inspections**

1) In-process and final examinations and tests shall be established to assure conformance with specifications,

drawings, instructions, and procedures which incorporate or reference the requirements and acceptance limits contained in applicable design documents. Examination activities to verify the quality of work shall be performed by persons other than those who performed the activity being examined. Such persons shall not report directly to the immediate supervisors responsible for the work being examined.

2) Process sheets, travelers, or checklists shall be prepared, including the document numbers and revision to which the examination or test is to be performed, with space provided for recording results.

3) Mandatory hold/inspection points at which witnessing is required by the "NR" Certificate Holder's representative or the Authorized Nuclear Inspector shall be indicated in the controlling documents. Work shall not proceed beyond mandatory hold/inspection points without the consent of the "NR" Certificate Holder's representative or the Authorized Nuclear Inspector, as appropriate.

#### **k) Test Control**

1) Testing shall be performed in accordance with the owner's written test procedures that incorporate or reference the requirements and acceptance limits contained in applicable design documents.

2) Test procedures shall include provisions for assuring that prerequisites for the given test have been met, that adequate instrumentation is available and used, and that necessary monitoring is performed. Prerequisites may include calibrated instrumentation, appropriate equipment, trained personnel, condition of test equipment and the item to be tested, suitable environmental conditions, and provisions for data acquisition.

3) Test results shall be documented and evaluated to assure that test requirements have been satisfied.

#### **l) Control of Measuring and Test Equipment**

Measures shall be established and documented to assure that tools, gages, instruments, and other measuring and testing equipment and devices used in activities affecting quality are of the proper range,

type, and accuracy to verify conformance to established requirements. A procedure shall be in effect to assure that they are calibrated and properly adjusted at specified periods or use intervals to maintain accuracy within specified limits. Calibration shall be traceable to known national standards, where these standards exist, or with the device manufacturer's recommendation.

m) Quality Records

1) The owner is responsible for designating records to be maintained. Measures shall be established for the "NR" Certificate Holder to maintain these records [See 1.8.5.1(m)(2)] required for Quality Assurance of repair/replacement activities. These shall include documents such as records of materials, manufacturing, examination, and test data taken before and during repair/replacement activity. Procedures, specifications, and drawings used shall be fully identified by pertinent material or item identification numbers, revision numbers, and issue dates. The records shall also include related data such as qualification of personnel, procedures, equipment, and related repairs. The "NR" Certificate Holder shall take such steps as may be required to provide suitable protection from deterioration and damage for all records while in his care. Also, it is required that the "NR" Certificate Holder have a system for correction or amending records that satisfies the owner's requirements. These records may be either the original or a reproduced, legible copy and shall be transferred to the owner at his request.

2) Records to be maintained as required in 1.8.5.1(m)(1) above may include the following:

- a. An index that details the location and who is responsible for maintaining the records;
- b. Data reports, properly executed, for each replacement component, part, appurtenance, piping system, and piping assembly, when required by the design specification or the owner;
- c. The required as-constructed drawings certified as to correctness;
- d. Copies of applicable Certified Material Test Reports and Certificates of Compliance;

e. As-built sketch(es) including tabulations of materials repair/replacement procedures, and instructions to achieve compliance with Section XI of the ASME Code;

f. Nondestructive examination reports including results of examinations shall identify the ASNT, SNT-TC-1A, CP-189, or ACCP level of personnel interpreting the examination results. The ASNT Central Certification Program (ACCP) may be used to fulfill the examination and demonstration requirement of the employer's written practice. Final radiographs shall be included where radiography has been performed;

g. Records of all heat treatments may be either the heat treatment charts or a summary description of heat treatment time and temperature data certified by the "NR" Certificate Holder. Heat treatments performed by the material manufacturer to satisfy requirements of the material specifications may be reported on the Certified Material Test Report; or

h. Any and all nonconformance reports shall satisfy IWA-4000 of Section XI of the ASME Code and shall be reconciled by the owner prior to certification of the Form NR-1 or NVR-1, as applicable.

3) After a repair/replacement activity, all records including audit reports required to verify compliance with the applicable engineering documents and the "NR" Certificate Holder's Quality System Program, except those required by the owner or listed in 1.8.5.1(m)(2)(a) thru (g) above, shall be maintained at a place mutually agreed upon by the owner and the "NR" Certificate Holder. These records shall be maintained for a period of five years after completion of the repair/replacement activity.

4) The original of the completed Form NR-1 or Form NVR-1, as applicable, shall be registered with the National Board and, if required, a copy forwarded to the Jurisdiction where the nuclear power plant is located.

#### **n) Examination or Test Status**

Measures shall be established to indicate examination and test status of parts, items, or components during the repair/replacement activity. The system used shall provide positive identification of the part, item, or component by means of stamps, labels, routing cards, or other acceptable methods. The system shall include any procedures or instructions to achieve compliance. Also, measures shall be provided for the identification of acceptable and unacceptable items. They shall also include procedures for control of status indicators, including the authority for application and removal of status indicators.

#### **o) Nonconforming Materials or Items**

Measures shall be established to control materials or items that do not conform to requirements in order to prevent their inadvertent use, including measures to identify and control the proper installation of items and to preclude nonconformance with the requirements of these rules. These measures shall include procedures for identification, documentation, segregation, and disposition. Nonconforming items shall be reviewed for acceptance, rejection, or repair in accordance with documented procedures. The responsibility and authority for the disposition of nonconforming items shall be defined. Repaired or modified items shall be re-examined in accordance with the applicable procedures. Measures that control further processing of a nonconforming or defective item, pending a decision on its disposition, shall be established and maintained. Ultimate disposition of nonconforming items shall be documented.

#### **p) Corrective Action**

1) Measures shall be established to ensure that conditions adverse to quality such as failures, malfunctions, deficiencies, deviations, defective material and equipment, and other nonconformances are promptly identified and corrected.

2) In the case of significant conditions adverse to quality, the measures shall also ensure that the cause of these conditions be determined and corrected to preclude repetition. The identification of significant conditions adverse to quality, the cause, and condition and the corrective action taken shall be documented and reported to the appropriate levels of management.

3) The requirements shall also extend to the performance of subcontractors' corrective action measures.

**q) Audits**

A comprehensive system of planned and periodic audits shall be carried out by the "NR" Certificate Holder's organization to ensure compliance with the Quality System Program and to determine its effectiveness. Audits shall be performed in accordance with written procedures or checklists by personnel not having direct responsibilities in the areas being audited. Audit results shall be documented by the auditing personnel for review by management having responsibility in that area. Follow-up action, including re-audit of deficient areas, shall be taken where indicated. Audit results shall be made available to the Authorized Nuclear Inspector.

**r) Authorized Nuclear Inspector**

Measures shall be taken to reference the commissioned Rules for National Board Authorized Nuclear Inspector, qualified in accordance with the Rules for National Board Inservice and New Construction Commissioned Inspectors, to ensure that the latest documents including the Quality System Program will be made available to the inspector. The Authorized Nuclear Inspector shall be consulted prior to the issuance of a repair/replacement program in order that the Inspector may select any inspection or hold points in the program. The Authorized Nuclear Inspector shall not sign Form NR-1 or Form NVR-1, as applicable, unless satisfied that all work carried out is in accordance with the NBIC, ASME Section XI, and any jurisdictional requirements.

**s) Exhibits**

Forms referenced in the Quality System Manual shall be explained in the text and included as part of the referencing document or as an appendix. Forms shall be controlled and identified to show the latest approved revision, exhibit name, and other corresponding references as stated in the Quality System manual.

### **1.5.1 ACCREDITATION PROCESS**

- a) The National Board administers accreditation programs for authorization of organizations performing repairs and alterations to pressure-retaining items and/or pressure relief valves.
- b) Any organization may apply to the National Board to obtain a Certificate of Authorization for the requested scope of activities. A review shall be conducted to evaluate the organization's quality system. The individual assigned to conduct the evaluation shall meet the qualification requirements prescribed by the National Board. Upon completion of the evaluation, any deficiencies within the organization's quality system will be documented and a recommendation will be made to the National Board regarding issuance of a Certificate of Authorization.
- c) As part of the accreditation process, an applicant's quality system is subject to a review. National Board procedures provide for the confidential review resulting in recommendations to issue or not issue a Certificate of Authorization.
- d) When the quality system requirements of this Section have been met, a Certificate of Authorization and appropriate National Board symbol stamp shall be issued.
- e) The accreditation programs provide requirements for organizations performing repairs and alterations to pressure-retaining items. Depending upon the expected scope of activities at the time of review, organizations may be authorized to perform design only, metallic or non-metallic repairs, and/or alterations either in the shop only, field only, or shop and field. Repairs and/or alterations to metallic and non-metallic pressure-retaining items are made by welding, bonding and/or mechanical assembly.

### **1.5.2 SCOPE ISSUANCE AND REVISION TO A QUALITY SYSTEM**

- a) Any scope revision shall require authorized inspection agency acceptance of quality system changes. These changes shall be submitted to the National Board for acceptance. A program review may be required by the National Board or the Jurisdiction to ensure quality system requirements are met for scope changes. Upon acceptance of the changes, the National Board will issue a Certificate of Authorization with a revised scope.
- b) The "VR" accreditation program provides requirements for organizations performing repairs to pressure relief valves. For scope issuance and revisions, refer to 1.7.

## **1.6 ACCREDITATION OF "R" REPAIR ORGANIZATIONS**

### **1.6.1 SCOPE**

- a) This section provides requirements that must be met by organizations in order to obtain a National Board Certificate of Authorization to use the "R" Symbol Stamp for the

repair or alteration of pressure-retaining items. Organizations may be authorized to perform repairs only, or repairs and alterations.

b) The issuance of the "R" Stamp is not restricted to organizations whose primary business is to repair and alter pressure-retaining items, nor to manufacturers of pressure-retaining items. Owners and Users of pressure-retaining items and other organizations that qualify in accordance with these rules may also obtain the "R" Stamp.

c) Owners or users may be accredited for both a repair and inspection program provided the owner or user complies with the requirements of the "R" program and the National Board requirements of NB 371 for an Owner-User Inspection Organization. The requirements of 1.6.2(a) do not apply if the owner or user chooses to use the Owner-User Inspection Organization to accept the repair quality system when:

- 1) There is no conflict with jurisdictional requirements.
- 2) The line of authority for the Owner-User Inspection Organization shall be independent of the organization responsible for execution of "R" program work.
- 3) The process and Inspector limitations are described in the written Owner-User Inspection Organization's quality system manual.

#### **1.6.2 PREREQUISITES FOR ISSUING A NATIONAL BOARD CERTIFICATE OF AUTHORIZATION**

Before an organization can obtain a National Board "R" Certificate of Authorization, the organization shall:

- a) Have and maintain an Inspection Agreement with an Authorized Inspection Agency;
- b) Have, in the English language, a written Quality System that complies with the requirements of this section and includes the expected scope of activities;
- c) Have the current edition and addendum of the National Board Inspection Code, all parts; and
- d) Have available a copy of the code of construction appropriate to the intended scope of work.

#### **1.6.3 PROCEDURE FOR OBTAINING OR RENEWING A NATIONAL BOARD CERTIFICATE OF AUTHORIZATION**

a) Prior to issuance or renewal of a National Board "R" Certificate of Authorization, the organization and its facilities are subject to a review of its Quality System. The implementation of the Quality System shall be satisfactorily demonstrated by the

organization. The National Board reserves the absolute right to cancel, refuse to issue, or renew such authorization.

b) Organizations desiring to renew or obtain a National Board Certificate of Authorization shall apply to the National Board using forms obtained from the National Board. Application for renewal shall be made prior to the expiration date of the Certificate of Authorization.

c) When an organization has plants or shops in more than one location, the organization shall submit separate applications for each plant or shop. The organization may perform repairs or alterations in its plants, shops, or in the field, provided such operations are described in the organization's Quality System.

d) Upon notification of the review dates from the National Board, it is the responsibility of the organization to make arrangements for the review.

e) The Review Team, as a minimum, shall consist of one representative each from the Authorized Inspection Agency and the Jurisdiction.<sup>2</sup>

f) The Review Team shall conduct an evaluation of the organization's Quality System. The organization shall demonstrate sufficient implementation of the Quality System to provide evidence of the organization's knowledge of welding, nondestructive examination, postweld heat treatment, and other repair or alteration activities performed appropriate for the requested scope of work. The demonstration may be performed using current work, a demonstration mock-up, or a combination of both.

g) A recommendation to issue, renew, or withhold the National Board Certificate of Authorization shall be included in a Review Report prepared by the Review Team. The completed Review Report shall be forwarded to the National Board.

h) If proper administrative fees are paid and all other requirements are met, a Certificate of Authorization will be issued evidencing permission to use the "R" Symbol Stamp. The certificate shall expire on the triennial anniversary date.

i) When an organization holding a National Board Certificate of Authorization changes ownership, name, location, or address, the National Board shall be notified. The Certificate of Authorization may be revised by submitting an application for National Board "R" Certificate of Authorization; however, a re-review may be required.

j) The holder of an ASME Code Symbol Stamp, whose facilities were reviewed (with the exception of "V," "UV," "HV," "NV," and "H" [cast iron]) may obtain National Board authorization without a review of its facilities, provided:

1) The organization has a Quality System to cover the scope of the repairs or alterations to be made, subject to review by the Jurisdiction; and

2) The application for the "R" Certificate of Authorization is submitted within 12 months from the issuance of the ASME Certificate of Authorization. The initial Certificate of Authorization shall be issued to expire concurrent with the ASME Certificate of Authorization. Subsequent certificates shall be renewed upon a successful review and implementation of its Quality System by a National Board Representative.

k) The Jurisdiction may audit the Quality System and activities of an organization upon a valid request from an owner, user, inspection agency, or the National Board.

l) The NBIC Committee may at any time change the rules for the issuance of Certificates of Authorization and use of the "R" Symbol Stamp. These rules shall become binding on all certificate holders.

#### **1.6.4 NATIONAL BOARD "R" SYMBOL STAMP**

a) All "R" Symbol Stamps shall be obtained from the National Board of Boiler and Pressure Vessel Inspectors. Authorization to use the "R" Symbol Stamp may be granted by the National Board at its absolute discretion.

b) The "R" Symbol Stamp is furnished on loan by the National Board for a nominal fee. Each organization shall agree if authorization to use the "R" Symbol Stamp is granted, that the "R" Symbol Stamp is at all times the property of the National Board and will be promptly returned upon demand. If the organization discontinues the use of the "R" Symbol Stamp, inspection agreement with an Authorized Inspection Agency, or if the Certificate of Authorization has expired and no new certificate has been issued, the "R" Symbol Stamp shall be returned to the National Board.

c) The organization's Quality System shall provide for adequate control of the "R" Symbol Stamp. Provisions may be made for the issuance of the "R" Symbol Stamp for use at various field locations.

d) The holder of a Certificate of Authorization may obtain more than one "R" Symbol Stamp provided the organization's Quality System describes how the use of such stamps is controlled from the location shown on the certificate.

e) An organization shall not permit others to use the "R" Symbol Stamp loaned to it by the National Board.

<sup>2</sup> Jurisdiction: The National Board member jurisdiction where the organization is located. Alternatively, where the Jurisdiction elects not to perform the review or where there is no Jurisdiction or where the Jurisdiction is the organization's Authorized Inspection Agency, the National Board of Boiler and Pressure Vessel Inspectors will represent the Jurisdiction. At the Jurisdiction's discretion, the Jurisdiction may choose to be a member of the review team if the Jurisdiction chooses not to be the team leader.

## **1.6.5 QUALITY SYSTEM**

A holder of a National Board Certificate of Authorization shall have and maintain a written Quality System. The System shall satisfactorily meet the requirements of the NBIC and shall be available for review. The Quality System may be brief or voluminous, depending on the projected scope of work. It shall be treated confidentially by the National Board.

### **1.6.5.1 OUTLINE OF REQUIREMENTS FOR A QUALITY SYSTEM FOR QUALIFICATION FOR THE NATIONAL BOARD "R" CERTIFICATE OF AUTHORIZATION**

The following is a guide for required features of a Quality System which shall be included in the organization's Quality System Manual. As a minimum, each organization shall address the required features relative to the scope of work to be performed. Organizations shall explain their intent, capability and applicability for each required feature outlined in this section. Work may be subcontracted provided controls are clearly defined for maintaining full responsibility for code compliance by the National Board repair organization certifying the work.

#### **a) Title Page**

The name and complete address of the company to which the National Board Certificate of Authorization is issued shall be included on the Title Page of the Quality System Manual.

#### **b) Contents Page**

The manual should contain a page listing the contents of the manual by subject, number (if applicable), and revision number of each document.

#### **c) Scope of Work**

The manual shall clearly indicate the scope and type of repairs or alterations the organization is capable of and intends to carry out.

#### **d) Statement of Authority and Responsibility**

A dated Statement of Authority, signed by an officer of the organization, shall be included in the manual. Further, the Statement of Authority shall include:

- 1) A statement that all repairs or alterations carried out by the organization shall meet the requirements of the NBIC and the Jurisdiction, as applicable.
- 2) A statement that if there is a disagreement in the implementation of the Quality

## NB12-2001

### a) Proposed Revision:

Existing Text from Part 3, Section 5.13.4.1 (12) under *Instructions for Completing National Board Form "R" Reports:*

**12. Provide a summary describing the exact scope of work that was completed to a Pressure-Retaining Item (PRI). The information to be included when describing the scope of work shall consider items such as the nature of the repair or alteration characterized by the listed examples, the specific location of the work performed to the PRI, the method of repair used to include as applicable, the steps taken to remove a defect or as allowed by NBIC Part 3, 3.3.4.8 to remain in place, the welding process and procedure when used, any special processes required such as PWHT; noting the soak time and temperatures recorded, and any acceptable in-process and final NDE-examinations or tests performed. When additional space is needed to fully describe the scope of work, a Form R-4 shall be used and attached.**

### Proposed Revised Text:

**12. Provide a summary describing the exact scope of work that was completed to a Pressure-Retaining Item (PRI). The information to be included when describing the scope of work shall should consider items such as the nature of the repair or alteration (i.e. welding, grinding, plugging) characterized by the listed examples, the specific location of the work performed to the PRI, the method of repair used to include as applicable, the steps taken to remove a defect or as allowed by NBIC Part 3, 3.3.4.8 to remain in place, the welding process and procedure when used, and any special welding, NDE, PWHT or Pressure Test processes performed NOT in accordance with the original Code of Construction, but in accordance with the NBIC. with required such as PWHT; noting the soak time and temperatures recorded, and any acceptable in-process and final NDE-examinations or tests performed. When additional space is needed to fully describe the scope of work, a Form R-4 shall be used and attached.**

### b) Statement of Need:

Some AIA's are interpreting the latest words as being "mandatory" due to the use of the words "exact" and "shall". In discussing the issue with the Task Group assigned to address this issue in the past, it is my understanding that the intent was to encourage a summary of the Scope of Work and not a list of specific information that is already contained in customer turnover packages and Certificate Holders' historical records. The additional pages in the final Code Document submitted to the NB also adds costs to the Certificate Holder in preparation man hours as well as page charges incurred during the filing process with NB.

c) Background Information:

Code Document packages have tripled in size due to the need to re-list every work scope detail that is already contained in documentation provided to the customer, as well as that retained in the historical records of the Certificate Holder. Discussions with various AIA's also reveals an inconsistent interpretation of Instruction #12, with some seeing the latest words as clarifying past understandings, while others view the latest words as a totally new requirement and are demanding extensive detail never before included in the R-form document package. (A good example will be available to present to the Sub-group/committee at the July meeting).