


Date Distributed: December 15, 2009



**THE
NATIONAL
BOARD**
OF BOILER AND
PRESSURE VESSEL
INSPECTORS

**SUBGROUP
ON INSPECTION
GENERAL**

AGENDA

*Meeting of January 19, 2010
Austin, Texas*

The National Board of Boiler & Pressure Vessel Inspectors
1055 Crupper Avenue
Columbus, Ohio 43229-1183
Phone: (614)888-8320
FAX: (614)847-1828

1. **Call to Order – 8:00 a.m.**
2. **Announcements**
3. **Adoption of the Agenda**
4. **Approval of Minutes of July 2009**
5. **Review of the Roster (Attachment 1)**
6. **Interpretations**

There are no interpretations assigned to this subgroup.

7. Action Items (Attachment 2)

NB07-0905 Part 2 4.3.1-4.3.3 SC Inspection Review these sections for completeness and consistency in pressure testing. Mr. Cook suggested forming a task group from all three parts. A task group of, D. Parrish, and J. Yagen has been assigned. Included in the attachment is an email from Mr. Galanes requesting that his concern be addressed in this action item. (See Attachment 2)

July 2007

A progress report was given.

January 2008

A progress report was given.

July 2008

A progress report was given.

January 2009

A progress report was given.

July 2009

A progress report was given. Mark Horbaczewski replaced Ron Shapiro on the task group.

January 2010

Mr. Parrish is expected to report.

8. New Business

9. Future Meetings

July 2010, Columbus, Ohio

January 2011, Austin, Texas

10. Adjournment

Respectfully Submitted,

Bill Smith

Secretary

:rh

SG on Inspection General

| Member | Title | ExpirDate | Interest Category |
|--------------------------|--------------|------------------|--------------------------|
| Bacon, Steven E. | | 8/27/2012 | Users |
| Canonico, Dr. Domenic A. | | 8/27/2012 | General Interest |
| Dobbins, Robert | | 1/17/2011 | Auth Inpection Agencies |
| Getter, Jim | Chairman | 8/27/2012 | Manufacturer |
| Horbaczewski, Mark | | 1/17/2011 | Users |
| McRae, Greg | | 2/28/2011 | Manufacturer |
| Parrish, Dave | Vice Chair | 8/27/2012 | Auth Inpection Agencies |
| Richardson, John | | 8/27/2012 | Manufacturer |
| Smith, Bill | Secretary | | |
| Total Members: | | 8 | |

Attachment 2

NBIC Main Committee Task Group Action Block

Subject Pressure Testing Terminology in the NBIC

File Number 07-0905 **Prop. on Pg.**

Proposal Review current use of pressure testing terminology and revise as necessary to provide consistency of terminology across Parts 1-3 of the NBIC. Also, evaluate need for cautionary statement regarding low toughness materials subjected to pressure testing.

Explanation

Project Manager M. Horbaczewski

Task Group Galanes (CHAIR),
Parrish, Yagen,
and Horbaczewski.

Task Group **TG Meeting Date**
Negatives

Background

This task group (TG) has been re-assigned to report back to the NBIC main committee Chair. The purpose of this TG is to review pressure testing terminology as currently stated in the NBIC, and to recommend necessary revisions to provide consistency of pressure testing terminology for Parts 1-3 of the NBIC.

1a

1/3

NBIC Main Committee Task Group Action Block

NB07-0905

NBIC Glossary Revisions

Current Definition for Pressure Testing

Pressure Test — Prior to initial operation, the completed boiler, including pressure piping, water columns, superheaters, economizers, stop valves, etc., shall be pressure tested in a test performed in accordance with the original code of construction prior to initial operation of an installed unit that is witnessed by an Inspector.

Delete above.

Insert New Definitions below into the Glossary

Hydrostatic Test – a liquid pressure test that is performed in accordance with the requirements of the original code of construction.

Liquid Pressure Test - a test method using water or other liquid medium (which is incompressible) to verify the leak tightness integrity of a repair or to verify the leak tightness of a pressure retaining item. The liquid test pressure shall be the minimum required to verify the integrity of the repair or leak tightness of the pressure retaining item, as agreed upon between the Inspector and the owner-user.

Pneumatic Pressure test – a test method using an inert gas which shall not exceed the maximum pneumatic test pressure in the original code of construction (if applicable) or as agreed upon between the owner/user and Certificate holder.

Rationale;

The proposed change to the existing definition of pressure testing to liquid pressure testing captures the essence of using a liquid only. We now have identified the use of pneumatic pressure testing, where an inert gas is used versus a liquid.

2a 2/3

NBIC Main Committee Task Group Action Block

So, by having three forms of pressure testing identified in the Glossary, we can now go back and substitute in Part 1-3, terms where we can use Hydrotesting with reference to original code of construction followed by Liquid pressure testing to check for leaks or to verify leak integrity and finally we have pneumatic pressure testing as an alternative to Liquid Pressure testing.

I believe using the above definitions provides improved consistency and uniformity across all 3 parts of the NBIC. I deliberately chose not to address the definition of "Leak Test" because this can fall under a Liquid Pressure test OR pneumatic pressure test.

NBIC Main Committee Task Group Action Block

Subject Pressure Testing Terminology in the NBIC

File Number

07-0905

Prop. on Pg.

Proposal

Review current use of pressure testing terminology and revise as necessary to provide consistency of terminology across Parts 1-3 of the NBIC. Also, evaluate need for cautionary statement regarding low toughness materials subjected to pressure testing.

Explanation

Project Manager

TBD

Task Group

Galanes, Parrish,
Yagen, Horbaczewski,
and ?

Task Group

TG Meeting Date

Negatives

Background

This task group (TG) has been re-assigned to report back to the NBIC main committee Chair. The purpose of this TG is to review pressure testing terminology as currently stated in the NBIC, and to recommend necessary revisions to provide consistency of pressure testing terminology for Parts 1-3 of the NBIC.

NB07-0905 Part Revision Proposal July 17, 2009

| EXISTING TEXT | PROPOSED TEXT |
|--|--|
| <p>SECTION CODE • PART 2 — INSPECTION</p> <p>procedures. Alternatively, lines may be blanked or sections of pipe removed. Blowoff lines, where practicable, shall be disconnected between pressure parts and valves. All drains and vent lines shall be open.</p> <p>2) The Inspector shall review all personnel safety requirements as outlined in 1.4 prior to entry.</p> <p>Note: If a boiler has not been properly prepared for an internal inspection, the inspector shall decline to make the inspection.</p> <p>2.2.7 EVIDENCE OF LEAKAGE</p> <p>a) It is not normally necessary to remove insulating material, masonry, or fixed parts of a boiler for inspection, unless defects or deterioration are suspected or are commonly found in the particular type of boiler being inspected. Where there is evidence of leakage showing on the covering, the Inspector shall have the covering removed in order that a thorough inspection of the area may be made. Such inspection may require removal of insulating material, masonry, or fixed parts of the boiler.</p> <p>b) For additional information regarding a leak in a boiler or determining the extent of a possible defect, a leak test may be performed per 4.3.3.</p> | <p>pressure</p> <p>[replace "leak" with "pressure"]</p> |

08/2

2.3.3 EXTERNAL INSPECTION

The purpose of an external inspection is to provide information regarding the general condition of the pressure vessel. The following should be reviewed:

a) Insulation or Other Coverings

If it is found that external coverings such as insulation and corrosion-resistant linings are in good condition and there is no reason to suspect any unsafe condition behind them, it is not necessary to remove them for inspection of the vessel. However, it may be advisable to remove small portions of the coverings in order to investigate attachments, nozzles, and material conditions.

Note: Precautions should be taken when removing insulation while vessel is under pressure.

b) Evidence of Leakage

Any leakage of gas, vapor, or liquid should be investigated. Leakage coming from behind insulation coverings, supports or settings, or evidence of past leakage should be thoroughly investigated by removing any covering necessary until the source of leakage is established.

For additional information regarding a leak in a pressure vessel or determining the extent of a possible defect a pressure test may be performed per Section 4.3.1.

[add new text following 2.3.3, b]

3/20

NB07-0905 Part Revision Proposal July 17, 2009

| DN CODE • PART 2 — INSPECTION | |
|---|--|
| <p>2.4.6 EVIDENCE OF LEAKAGE</p> <p>a) A leak should be thoroughly investigated and corrective action initiated. Leaks beneath piping insulation should be approached with caution, especially when removing insulation from a pressurized piping system for inspection.</p> <p>b) A pressure test may be required to obtain additional information regarding the extent of a defect or detrimental condition.</p> <p>c) To determine tightness, the test pressure need be no greater than the normal operating pressure. The metal temperature should be not less than 70°F (21°C) and the maximum metal temperature during inspection should not exceed 120°F (49°C). The potential corrosive effect of the test fluid on the piping material should be considered.</p> | <p>[Replace 2.4.6 with following and delete part "c."]</p> <p>b) For additional information regarding a leak in piping or determining the extent of a possible defect a pressure test may be performed per Section 4.3.1.</p> <p>e) To determine tightness, the test pressure need be no greater than the normal operating pressure. The metal temperature should be not less than 70°F (21°C) and the maximum metal temperature during inspection should not exceed 120°F (49°C). The potential corrosive effect of the test fluid on the piping material should be considered.</p> |

4/20

NB07-0905 Part Revision Proposal July 17, 2009


| | |
|---|--|
| <p>3.4.9 CRACKS</p> <p>a) Cracks may result from flaws existing in material or excessive cyclic stresses. Cracking can be caused by fatigue of the metal due to continual flexing and may be accelerated by corrosion. Fire cracks are caused by the thermal differential when the cooling effect of the water is not adequate to transfer the heat from the metal surfaces exposed to the fire. Some cracks result from a combination of all these causes mentioned.</p> <p>A07 b) Cracks noted in shell plates and fire cracks that run from the edge of the plate into the rivet holes of girth seams should be repaired. Thermal fatigue cracks determined by engineering evaluation to be self arresting may be left in place.</p> <p>c) Areas where cracks are most likely to appear should be examined. This includes the ligaments between tube holes, from and between rivet holes, any flange where there may be repeated flexing of the plate during operation and around welded connections.</p> <p>d) Lap joints are subject to cracking where the plates lap in the longitudinal seam. If there is any evidence of leakage or other distress at this point, the Inspector shall thoroughly examine the area and, if necessary, have the plate notched or slotted in order to determine whether cracks exist in the seam. Repairs of lap joint cracks on longitudinal seams are prohibited.</p> <p>e) Where cracks are suspected, it may be necessary to subject the pressure-retaining item to a hydrostatic test or nondestructive examination to determine their presence and location.</p> <p>A07 f) Cracks shall either be repaired, or formally evaluated by Crack Propagation Analysis to quantify their existing mechanical integrity.</p> | <p>[Replace “hydrostatic” with “pressure” and add “a” preceding “nondestructive.”]</p> <p>e) Where cracks are suspected, it may be necessary to subject the pressure-retaining item to a pressure test or a nondestructive examination to determine their presence and location.</p> |
| <p>65</p> | |

5/20

| | |
|--|---|
| <p>it y a e r- is e e d</p> <p>4.3.1 PRESSURE TESTING</p> <p>a) During an inspection of a pressure-retaining item, there may be certain instances where inservice conditions have adversely affected the tightness of the component or the inspection discloses unusual, hard to evaluate forms of deterioration that may affect the safety of the vessel. In these specific instances, a pressure test using air, water, or other suitable test medium may be required at the discretion of the Inspector to assess leak tightness of the pressure-retaining item.</p> <p>b) The Inspector is cautioned that a pressure test will not provide any indication of the amount of remaining service life or the future reliability of a pressure-retaining item. The pressure test in this instance only serves to determine if the pressure-retaining item contains defects that will not allow the item to retain pressure. In certain instances, pressure tests of inservice components may reduce the remaining service life of the component due to causing permanent deformation of the item.</p> <p>d</p> <p>70</p> | <p>4.3.1. PRESSURE TESTING</p> <p>During an inspection of a pressure-retaining item, there may be certain instances where in-service conditions have adversely affected the tightness of the component or the inspection discloses unusual, hard to evaluate forms of deterioration that may affect the pressure retaining capability of the vessel. In these specific instances, a pressure test using air, water, or other suitable test medium may be required at the discretion of the Inspector to assess pressure boundary integrity of the pressure-retaining item.</p> <p>The Inspector is cautioned that a pressure test will not provide any indication of the amount of remaining service life or the future reliability of a pressure-retaining item. The pressure test only serves to determine if the pressure-retaining item contains defects that will not allow the item to retain pressure. In certain instances, pressure tests of in-service components may reduce the remaining service life of the component due to causing permanent deformation of the item.</p> |
|--|---|

6/20

NB07-0905 Part Revision Proposal July 17, 2009

| NATIONAL BOARD INSPECTION CODE | |
|--|---|
| <p>c) If an inservice pressure test is required, the following precautions shall be met:</p> <ol style="list-style-type: none"> 1) The test pressure should not exceed 90% of the set pressure of the lowest setting pressure relief device on the component to avoid damage to pressure relief devices. 2) Test pressure should be selected or adjusted in agreement between the Inspector and the owner-user. When the original test pressure includes consideration of corrosion allowance, the test pressure may be further adjusted based upon the remaining corrosion allowance. 3) The metal temperature during a pressure test should not be less than 60°F (16°C) unless the owner-user provides information on the toughness characteristics of the vessel material to indicate the acceptability of a lower test temperature. 4) The metal temperature shall not be more than 120°F (49°C) unless the owner-user specifies the requirement for a higher test temperature. If the owner-user specifies a test temperature higher than 120°F (49°C), then precautions shall be taken to afford the Inspector close examination without risk of injury. 5) When contamination of the vessel contents by any medium is prohibited or when a pressure test is not practical, other testing methods described below may be used provided the precautionary requirements of the applicable Section of the original construction code or other standards are followed. In such cases, there shall be agreement as to the testing procedure between the owner-user and the Inspector. | <p>4</p> <p>L i t t e s s i l r t p a i</p> <p>4</p> <p>F i s a</p> <p>a</p> <p>b</p> <p>Use of pressure test procedures shall be in agreement between the owner-user and the Inspector. Use of written procedures and experienced personnel is required when performing pressure tests. The Inspector shall review the written procedure to become familiar with limitations, adequacy, methods, and acceptance standards identified.</p> <p>All instrumentation, including pressure and temperature gages, used to monitor a pressure test shall be properly calibrated.</p> <p>When contamination of the vessel contents by water is prohibited or when a hydrostatic test is not practical due to weight or other considerations, other test mediums may be used provided the precautionary requirements of the applicable section of the original construction code or other standards are followed. In such cases, there shall be agreement as to the testing procedure between the owner-user and the Inspector.</p> <p>Pressure testing shall not be conducted using flammable or toxic fluids.</p> <p>NOTE: The requirements of NBIC Part 3 shall be followed when performing a pressure test following repair or alteration of a pressure retaining item.</p> <p>The following precautions shall be considered when conducting a pressure test of an inservice pressure retaining item:</p> <p>ALL PRESSURE TESTING:</p>  |
| 71 | |

7/00

the test media. Some types of steel and low alloy steels may not have sufficient notch toughness to prevent brittle fracture during pressure testing conducted at or even above the minimum applicable temperature. In these instances, the user should select a different type of steel material to evaluate the notch toughness characteristics of the steel material. Some properties of material and test media temperature may be specified.

The organization performing the test shall determine the test media and the test media temperature. The test media and the test media temperature shall be specified at the submission of the test media and the test media temperature.

HYDROSTATIC TEST:

A hydrostatic test is the preferred method for conducting a pressure test.

Test pressure should be selected or adjusted in agreement between the Inspector and the owner-user.

The test pressure should not exceed 90% of the set pressure of the lowest setting pressure relief device on the component to avoid damage to pressure relief devices.

The hydrostatic test pressure must not exceed 150% of the MAWP.

During a hydrostatic test where the test pressure will exceed 90% of the set pressure of a pressure relief device, the device shall be removed whenever possible. If not possible or practical, a spindle restraint such as a gag may be used provided that the valve manufacturer's instructions and recommendations are followed. Extreme caution should be

2/20

| | |
|--|--|
| | <p>employed to ensure only enough force is applied to contain pressure. Excessive mechanical force applied to the spindle restraint may result in damage to the seat and/or spindle and may interfere with the proper operation of the valve. The spindle restraint shall be removed following the test.</p> <p>The organization who performs the hydrostatic test and applies a spindle restraint shall attach a metal tag that identifies the organization and date the work was performed to the pressure-relieving device. If the seal was broken, the organization shall reseal the adjustment housing with a seal that identifies the responsible organization. The process shall be acceptable to the jurisdiction where the pressure-retaining items are installed.</p> <p>The metal temperature during hydrostatic test should not exceed 120°F (49°C) unless the owner-user specifies a higher test temperature. If the owner-user specifies a test temperature higher than 120°F (49°C), then precautions shall be taken to afford the Inspector close examination without risk of injury.</p> <p>Hold-time for the hydrostatic test shall be for a minimum of 10 minutes prior to the examination by the Inspector. Test pressure shall be maintained for the time necessary for the Inspector to conduct the inspection.</p> <p>PNEUMATIC TEST</p> |
|--|--|

9/20

NB07-0905 Part Revision Proposal July 17, 2009

| | |
|--|--|
| | <p>A pressure test using a compressible gas should not be performed unless a pressure test using a non-compressible fluid will damage the pressure retaining item or cause contamination of the internal surfaces of the pressure retaining item.</p> <p>Due to the volumetric expansion potential of a pressurized compressible fluid, adequate safety precautions must be taken to ensure personnel safety.</p> <p>Properly calibrated instrumentation shall be used to detect leakage of the testing medium. The instrumentation selected shall be appropriate for the test medium. Instrumentation may detect changes in pressure or chemical concentrations and shall be sensitive enough to detect leakage.</p> <p>A pneumatic test using air as a test medium may be conducted without using instrumentation provided that the inspection is performed using a bubble test. Test pressure for a pneumatic bubble test is not to exceed the lesser of 10% of the pressure retaining item operating pressure or 5 psig.</p> |
|--|--|

10/20

NB07-0905 Part Revision Proposal July 17, 2009

| IDN CODE * PART 2 - INSPECTION | |
|--|--|
| <p>he 4.3.2 LEAK TESTING</p> <p>ed Leak testing for the purpose of detecting any est leakage may be performed when a pressure he test cannot be performed. Some methods or ps- techniques for leak testing may include bubble test (direct pressure or vacuum), helium mass spectrometer, pressure change, or flow mea- surement. Use of leak test procedures shall be in agreement between the owner-user and the or Inspector. Use of written procedures and experi- he en-rienced personnel is required when performing leak tests. The Inspector shall review the written n- procedure to become familiar with limitations, he adequacy, methods, and acceptance standards ed identified.</p> | <p>4.3.2 LEAK TESTING</p> <p>Leak testing for the purpose of detecting significant pressure boundary leakage may be performed. A leak test is conducted by filling the PRI with the normal operating fluid at ambient pressure and temperature. The PRI is visually examined for signs of leakage.</p> |
| <p>ps- 4.3.3 EVIDENCE OF LEAKAGE IN A EF BOILER</p> <p>ec For additional understanding regarding a leak er- in a boiler, see 2.2.7 for the extent of a possi- ite ble defect. A pressure test may be performed n- as follows:</p> <p>be a) To determine tightness, the test pressure he shall be no greater than the maximum al- nt lowable working pressure stamped on the he pressure-retaining item.</p> <p>ire b) During a pressure test where the test pres- u- sure will exceed 90% of the set pressure of ic- a pressure relief device, the device shall be of removed whenever possible. If not possible or practical, a spindle restraint such as a el gag may be used provided that the valve ed manufacturer's instructions and recom- al. mendations are followed. Extreme caution iv should be employed to ensure only enough n- force is applied to contain pressure. Exces- ile sive mechanical force applied to the spindle on restraint may result in damage to the seat d. and/or spindle and may interfere with the nt proper operation of the valve. The spindle he restraint shall be removed following the test.</p> | <p><u>4.3.3 Delete</u></p> |

1/20

NB07-0905 Part Revision Proposal July 17, 2009

| | |
|--|---|
| <p>5.11 fro- g of tion ders ean nger less pol- ical nta- ged tory nti-</p> <p>lec- age</p> <p>ver- s to</p> <p>n of</p> <p>B 1</p> | <p>c) Components subjected to fire damage can exhibit altered mechanical properties, and should be evaluated to determine if the material has retained necessary strength and toughness as specified in the original code of construction. Heating above the lower critical temperature results in a phase transformation that upon rapid cooling can dramatically affect material properties. Evaluation methods may consist of:</p> <ol style="list-style-type: none">1) Portable hardness testing2) Field metallography or replication3) Pressure testing4) Magnetic particle testing5) Liquid penetrant testing6) Visual examination7) Dimensional verification checks <p>d) If visual distortion or changes in the microstructure or mechanical properties are noted, consider replacing the component or a detailed engineering analysis shall be performed to verify continued safe operation.</p> <p>e) Techniques for evaluating fire damage are referenced in applicable standards. See 1.3.</p> <p><u>3) Pressure testing</u></p> |
| | |

D/2

NB07-0905 Part Revision Proposal July 17, 2009

FORM NB-5 BOILER OR PRESSURE VESSEL DATA REPORT
FIRST INTERNAL INSPECTION
 Standard Form for Jurisdictions Operating Under the ASME Code

| | | | | | | | | |
|----|---|------------------------------|--|---|---|------------------------------------|------------------------------------|-----|
| 1 | DATE INSPECTED MO. DAY YEAR | CERTIFY DATE MO. YEAR | CERTIFICATE FORCED <input type="checkbox"/> Yes <input type="checkbox"/> No | OWNER NO. | JURISDICTION NUMBER | FILED NO. <input type="checkbox"/> | OTHER NO. <input type="checkbox"/> | |
| 2 | OWNER | NATURE OF BUSINESS | KIND OF INSPECTION <input type="checkbox"/> Full <input type="checkbox"/> Partial | CERTIFICATE INSPECTION <input type="checkbox"/> Yes <input type="checkbox"/> No | OWNER'S STREET ADDRESS NUMBER | OWNER'S CITY | STATE | ZIP |
| 3 | USER'S NAME - OBJECT LOCATION | SPECIFIC LOCATION IN PLANT | OBJECT LOCATION - COUNTY | USER'S STREET ADDRESS NUMBER | USER'S CITY | STATE | ZIP | |
| 4 | TYPE <input type="checkbox"/> HT <input type="checkbox"/> WT <input type="checkbox"/> OD <input type="checkbox"/> AIR TANK <input type="checkbox"/> WIND TANK | YEAR BUILT | MANUFACTURER | YEAR INST. | <input type="checkbox"/> New <input type="checkbox"/> Rebuilt | | | |
| 5 | IS <input type="checkbox"/> Fire <input type="checkbox"/> Process <input type="checkbox"/> Heating <input type="checkbox"/> Power <input type="checkbox"/> Other | FUEL OR LIQ. | METHOD OF PRING. (BOILER) | PRESSURE GAGE TESTED <input type="checkbox"/> Yes <input type="checkbox"/> No | | | | |
| 6 | TESTS Subsequent | SAFETY RELIEF VALVES Make | EXPLAIN IF PRESSURE CHANGED | | | | | |
| 7 | IF CONDITION OF OBJECT SUCH THAT ACCEPTANCE MAY BE ISSUED? | | | | HYDRO TEST <input type="checkbox"/> Yes <input type="checkbox"/> No | | | |
| 8 | WELL | DIAMETER | OVERALL LENGTH | THICKNESS | TOTAL WTS. SURFACE | INTERNAL | | |
| 9 | ALLOWABLE STRESS | SAFETY STRIP | HEADERS W/ SCALDS | TYPE | <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Other | | | |
| 10 | THE LONGITUDINAL SEAM | WELDED | WELDED | WELDED | WELDED | SEAM EFF. | | |
| 11 | HEAD THICKNESS | WELDED | WELDED | WELDED | WELDED | BOLTING | | |
| 12 | FLUE SHEET THICKNESS | TUBES | WELDED | WELDED | WELDED | WELDED | | |
| 13 | STAYS AND FITTINGS | STAYS BELT FITTINGS | STAYS | STAYS | STAYS | STAYS | | |
| 14 | STAYS | STAYS | STAYS | STAYS | STAYS | STAYS | | |
| 15 | STAYS | STAYS | STAYS | STAYS | STAYS | STAYS | | |
| 16 | SAFETY RELIEF VALVES | TOTAL TANK | WELDED | WELDED | WELDED | WELDED | | |
| 17 | STOP VALVES | ON STEAM LINE | ON RETURN LINES | OTHER CONNECTIONS | STEAM LINES PROPERLY DRAINED | | | |
| 18 | FEED PIPE | FEED APPLIANCES | FEED CHUTE | FEED LINE | FEED LINE | RETURN LINE | | |
| 19 | WATER GAGE GLASS | TRICOCKS | BLOWOFF PIPE | WELDED | WELDED | WELDED | | |
| 20 | WELDED | WELDED | WELDED | WELDED | WELDED | WELDED | | |
| 21 | WELDED | WELDED | WELDED | WELDED | WELDED | WELDED | | |
| 22 | NAME AND TITLE OF PERSON TO WHOM REQUIREMENTS WERE EXPLAINED | | | | | | | |
| 23 | INSPECTOR CERTIFIES THIS IS A TRUE REPORT OF MY INSPECTION | | | CONTACT | EMPLOYED BY | IDENT. NO. | | |

Replace
 "Hydro"
 with
 "Pressure."

Circle on Whatnots Plus if need National Board

Circle when no Requirements Board

This form may be obtained from The National Board of Boiler and Pressure Vessel Inspectors, 1865 Claddon Ave., Columbus, OH 43222

13/21

NB07-0905 Part Revision Proposal July 17, 2009

| FORM NB-6 BOILER FIRED PRESSURE VESSELS | | | | | | | | | |
|---|--|----------------------------|--------------------------------------|--------------------------------|---------------------------------------|---------------------------------------|------------------------------------|------------|--|
| REPORT OF INSPECTION | | | | | | | | | |
| 1 | Date Inspected Mo / Day / Year | Cont Exp Date Mo / Year | Certificate Posted Yes ___ No ___ | Owner No. | Jurisdiction Number | NB No. | Other No. | | |
| 2 | Owner | | | Nature of Business | Kind of Inspection Int ___ Ext ___ | | Certificate Insp Yes ___ No ___ | | |
| 3 | Owner Street Address Number | | | Owners City | State | ZIP Code | | | |
| 4 | User's Name - Object Location | | | Specific Location In Plant | | Object Location - County | | | |
| 5 | User's Street Address Number | | | User's City | State | ZIP Code | | | |
| 6 | Type FT ___ WT ___ CI ___ Other ___ | | | Year Built | Manufacturer | | | | |
| 7 | Use Power ___ Process ___ Steam Htg ___ HW Htg ___ HW Storage ___ | | | Fuel (Boiler) | Method of Firing (Boiler) | Pressure Gage Tested | | | |
| 8 | Pressure MAWP | | | Safety-Relief Valves Set at | | Heating Surface or RTU (Input/Output) | | | |
| 9 | This inspection | | | Prev. inspection | | Total Capacity | | | |
| 10 | Is condition of object such that a certificate may be issued? | | | Hydro test | | Date | | | |
| 11 | Yes ___ No (if no, explain fully under conditions) ___ | | | Set at | | Date | | | |
| 12 | <p>Conditions: With respect to the internal surface, describe and state location of any scale, oil or other deposits. Give location and extent of any corrosion and state whether active or inactive. State location and extent of any erosion, pitting, bulging, cracking or similar condition. Report on any defective rivets, leakers, loose or broken stays. State condition of all tubes, tube ends, coils, nipples, etc. Describe any adverse conditions with respect to pressure gages, water columns, gage glasses, gage cocks, safety valves, etc. Report condition of seating, fittings, bolts, supports, etc. Describe any major changes or repairs made since last inspection.</p> | | | | | | | | |
| 13 | Requirements: (List Code Violations) | | | | | | | | |
| 14 | Name and Title of Person to Whom Requirements Were Explained: | | | | | | | | |
| 15 | I hereby Certify This is A True Report Of My Inspection | | | | | | | | |
| 16 | Signature of Inspector | | | Ident. No. | Employed By | | | Ident. No. | |

Replace
"Hydro" with
"Pressure."

14/24

NB07-0905 Part Revision Proposal July 17, 2009

**FORM NB-7 PRESSURE VESSELS
REPORT OF INSPECTION**
Standard Form for Jurisdictionless Operating Under the ASME Code

| | | | | | | |
|----|---|--------------------------|---|--|--|---|
| 1 | DATE INSPECTED MO DAY YEAR | CERT. EXPIRES MO YEAR | CERTIFICATE POSTED <input type="checkbox"/> Y <input type="checkbox"/> N | OWNER NO. | JURISDICTION NUMBER | NATL. ID. NO. <input type="checkbox"/> OTHER NO. <input type="checkbox"/> |
| 2 | OWNER OWNER'S STREET ADDRESS | | | NATURE OF BUSINESS OWNER'S CITY | | KIND OF INSPECTION <input type="checkbox"/> R <input type="checkbox"/> SA CERTIFICATE INSPECTION <input type="checkbox"/> Y <input type="checkbox"/> N |
| 3 | USER'S NAME - STREET LOCATION USER'S STREET ADDRESS | | | SPECIFIC LOCATION PARAGRAPH USER'S CITY | | DISTRICT/COUNTY STATE ZIP |
| 4 | TYPE <input type="checkbox"/> LATE TANK <input type="checkbox"/> WATER TANK <input type="checkbox"/> OTHER | | | YEAR BUILT | MANUFACTURER | |
| 5 | USE <input type="checkbox"/> STORAGE <input type="checkbox"/> PROCESS <input type="checkbox"/> HEAT EXCHANGER <input type="checkbox"/> OTHER | | | SIZE | PRESSURE GAUGE TESTED <input type="checkbox"/> Y <input type="checkbox"/> N | |
| 6 | PRESSURE ALLOWED THIS INSPECTION | | PREVIOUS INSPECTION | SAFETY VALVES SET AT | TOTAL CAPACITY | EXPLAIN IF PRESSURE CHANGED |
| 7 | IS CONDITION OF OBJECT SUCH THAT A CERTIFICATE MAY BE ISSUED? <input type="checkbox"/> YES <input type="checkbox"/> NO IF NO EXPLAIN FULLY UNDER (8) BELOW | | | | | HYDRO TEST <input type="checkbox"/> YES <input type="checkbox"/> NO DATE |
| 8 | CONDITIONS: THE INSPECTOR IS RESPONSIBLE FOR THE INSPECTION OF THE VESSEL AND FOR THE ACCURACY OF THE REPORT. IT IS THE USER'S RESPONSIBILITY TO REPORT ANY DEFECTS OR VIOLATIONS TO THE INSPECTOR. AS NECESSARY, HE SHOULD BE MADE AWARE OF THE RESULTS OF THE INSPECTION. | | | | | |
| 9 | ADDITIONAL DEFECTS OR VIOLATIONS: <div style="border: 1px solid black; padding: 5px; width: fit-content; margin: 0 auto;"> Replace "Hydro" with "Pressure." </div> | | | | | |
| 10 | PARAGRAPH TITLE OF PARAGRAPH TO WHICH REQUIREMENTS WERE APPLIED INSPECTOR'S SIGNATURE AND TITLE DATE OF INSPECTION EMPLOYER'S NAME EMPLOYEE'S NAME SIGNATURE OF INSPECTOR | | | | | |

This form may be obtained from The National Board of Boiler and Pressure Vessel Inspectors, 3300 Clacker Ave., Columbus, OH 43220

NB-7 Rev. 2

i) Broken staybolts may be detected by leakage through telltale holes and by hammer testing. Both methods are most effective when the boiler is under hydrostatic pressure of at least 95% MAWP. If a hydrostatic test cannot be applied, the hammer test may be performed alone with the boiler drained.

In Part 2 - Supplement 1, there are several references to hammer testing staybolts while a hydrostatic test is being conducted. The Task Group recommends that this practice be further evaluated to ensure that personnel safety and integrity of the equipment is not jeopardized.

S1.4 LOCOMOTIVE FIRETUBE BOILER INSPECTION

15/20

NB07-0905 Part Revision Proposal July 17, 2009

| | |
|---|--|
| | <p>S1.4.1 INSPECTION METHODS</p> <p>i.) Broken staybolts may be detected by leakage through telltale holes and by hammer testing. Both methods are most effective when the boiler is under hydrostatic pressure of at least 95% MAWP. If a hydrostatic test cannot be applied, the hammer test may be performed alone with the boiler drained.</p> |
| <p align="center">NATIONAL BOARD INSPECTION</p> <p>SUPPLEMENT 2 HISTORICAL BOILERS</p> <p>S2.1 SCOPE</p> <p>a) This supplement is provided as a guide to inspection of historical steam boilers of riveted and/or welded construction not falling under the scope of Supplement 1. These historical steam boilers would include: steam tractors, traction engines, hobby steam boilers, portable steam boilers, and other such boilers that are being preserved, restored, and maintained for demonstration, viewing, or educational purposes.</p> <p>07 Note: This supplement is not to be used for steam locomotive boilers falling under the requirements of the Federal Railroad Administration (FRA). FRA rules for steam locomotive boilers are published in 49 CFR 230. Specific rules and special requirements for inspection, repairs, alterations, and storage of steam locomotive boilers are identified in Supplement 1 of the NBIC.</p> <p>b) The rules specified in this supplement shall be used in conjunction with the applicable rules in this Code. References specified or contained in this Supplement may provide additional information to assist the user when applying the requirements of this supplement.</p> <p>S2.2 INTRODUCTION</p> | <p>Supplement 2, there are several references to pressure testing.</p> <p>S 2.6 contains a safety warning that is in direct contradiction to guidance provided in Section 4.3.1. The Task Group strongly recommends that the safety warning be deleted from Supplement 2.</p> <p>The Task Group recommends that all pressure test requirements currently found in supplement 2 be deleted. Supplement 2 should reference Section 4.3.1 and 4.3.2 where necessary.</p> <p>The Task Group recommends that recurring pressure test requirements for historical boilers be further evaluated to ensure that integrity of the equipment is not jeopardized.</p> |

10/21

NB07-0905 Part Revision Proposal July 17, 2009

| NATIONAL BOARD INSPECTION CODE | |
|---|---|
| b) Common evidence of exposure to fire is: | S7 |
| 1) charring or burning of the paint or other protective coat; | Tt or sh |
| 2) burning or scarring of the metal; | be |
| 3) distortion; or | S7 |
| 4) burning or melting of the valves. | Ct |
| c) A pressure vessel that has been subjected to the action of fire shall be removed from service until it has been properly evaluated. The general intent of this requirement is to remove from service pressure vessels which have been subject to the action of fire that has changed the metallurgical structure or the strength properties of the steel. Visual examination with emphasis given to the condition of the protective coating can be used to evaluate exposure from a fire. This is normally determined by visual examination as described above with particular emphasis given to the condition of the protective coating. If there is evidence that the protective coating has been burned off any portion of the pressure vessel surface, or if the pressure vessel is burned, warped, or distorted, it is assumed that the pressure vessel has been overheated. If, however, the protective coating is only smudged, discolored, or blistered, and is found by examination to be intact underneath, the pressure vessel shall not be considered affected within the scope of this requirement. Vessels that have been involved in a fire and show no distortion shall be requalified for continued service by retesting using the hydrostatic test procedure applicable at the time of original fabrication. | wt tif ur or vir S7 a: b) c) |
| 37 | [Replace "hydrostatic" with "pressure" in part "c"] pressure |

17/20

NB07-0905 Part Revision Proposal July 17, 2009

| NATIONAL BOARD INSPECTION CODE | |
|---|--|
| Dutchman — Generally limited to tube or pipe cross-section replacement. The work necessary to remove a compromised section of material and replace the section with material meeting the service requirements and installation procedures acceptable to the Inspector. Also recognized as piecing. | Lift aux spi sur |
| Examination — In process work denoting the act of performing or completing a task of interrogation of compliance. Visual observations, radiography, liquid penetrant, magnetic particle, and ultrasonic methods are recognized examples of examination techniques. | Ma me anc of r |
| Exit — A doorway, hallway, or similar passage that will allow free, normally upright unencumbered egress from an area. | Me est ary pre thr intr NB |
| Field — A temporary location, under the control of the Certificate Holder, that is used for repairs and/or alterations to pressure-retaining items at an address different from that shown on the Certificate Holder's <i>Certificate of Authorization</i> . | Me rep boi ing boi we of t |
| Forced-Flow Steam Generator — A steam generator with a forced steamline and waterline. | NB pul Pre |
| Inspection — A process of review to ensure engineering design, materials, assembly, examination and testing requirements have been met and are compliant with the Code. | "N por rize |
| Inspector — See National Board Commissioned Inspector and National Board Owner-User Commissioned Inspector. | Na anc |
| Intervening — Coming between or inserted between, as between the test vessel and the valve being tested. | Na An Na |
| Jurisdiction — A governmental entity with the power, right, or authority to interpret and enforce law, rules, or ordinances pertaining to boilers, pressure vessels, or other pressure-retaining items. It includes National Board member jurisdictions defined as "jurisdictional authorities." | Nu dar nuc |
| Jurisdictional Authority — A member of the National Board, as defined in the National Board Constitution. | Or pro wri me ore wa |

[Insert new description of "Hydrostatic test".]

Hydrostatic test – A pressure test which is conducted using water or another appropriate liquid as the test medium.

18/20

NB07-0905 Part Revision Proposal July 17, 2009

| <p>SECTION CODE • PART 2 — INSPECTION</p> | |
|--|--|
| <p>pe ry ial et- on so</p> <p>Lift Assist Device — A device used to apply an auxiliary load to a pressure relief valve stem or spindle, used to determine the valve set pressure as an alternative to a full pressure test.</p> | <p>Leak Test – An examination that is conducted using the normal operating fluid of a PRI at ambient pressure and temperature. The PRI is visually examined for signs of leakage. A leak test is used to determine if there are significant pressure boundary integrity issues.</p> |
| <p>he er- ns. ar- ed</p> <p>Manufacturer's Documentation — The documentation that includes technical information and certification required by the original code of construction.</p> | |
| <p>ge m-</p> <p>Mechanical Assembly — The work necessary to establish or restore a pressure retaining boundary, under supplementary materials, whereby pressure-retaining capability is established through a mechanical, chemical, or physical interface, as defined under the rules of the NBIC.</p> | <p>[Insert new description of "Leak Test."]</p> |
| <p>ol irs at er-</p> <p>Mechanical Repair Method — A method of repair, which restores a pressure retaining boundary to a safe and satisfactory operating condition, where the pressure retaining boundary is established by a method other than welding or blazing, as defined under the rules of the NBIC.</p> | |
| <p>n- e.</p> <p>NBIC — The <i>National Board Inspection Code</i> published by The National Board of Boiler and Pressure Vessel Inspectors.</p> | |
| <p>ire ix- en</p> <p>"NR" Certificate Holder — An organization in possession of a valid "NR" <i>Certificate of Authorization</i> issued by the National Board.</p> | |
| <p>is- er-</p> <p>National Board — The National Board of Boiler and Pressure Vessel Inspectors.</p> | |
| <p>ed he</p> <p>National Board Commissioned Inspector — An individual who holds a valid and current National Board Commission.</p> | |
| <p>he ce rs.</p> <p>Nuclear Items — Items constructed in accordance with recognized standards to be used in nuclear power plants or fuel processing facilities.</p> | |
| <p>ng is- "</p> <p>Original Code of Construction — Documents promulgated by recognized national standards writing bodies that contain technical requirements for construction of pressure-retaining items or equivalent to which the pressure-retaining item was certified by the original manufacturer.</p> | |
| <p>275</p> | |

19/20

NATIONAL BOARD INSPECTION CODE •

Owner or User — As referenced in lower case letters means any person, firm, or corporation legally responsible for the safe operation of any pressure-retaining item.

Owner-User Inspection Organization — An owner or user of pressure-retaining items that maintains an established inspection program, whose organization and inspection procedures meet the requirements of the National Board rules and are acceptable to the jurisdiction or jurisdictional authority wherein the owner or user is located.

Owner-User Inspector — An individual who holds a valid and current National Board Owner-User Commission.

Piecing — A repair method used to remove and replace a portion of piping or tubing material with suitable material and installation procedure.

Pressure-Retaining Items (PRI) — Any boiler, pressure vessel, piping, or material used for the containment of pressure, either internal or external. The pressure may be obtained from an external source, or by the application of heat from a direct source, or any combination thereof.

Pressure Test — Prior to initial operation, the completed boiler, including pressure piping, water columns, superheaters, economizers, stop valves, etc., shall be pressure tested in a test performed in accordance with the original code of construction prior to initial operation of an installed unit that is witnessed by an Inspector.

Repair — The work necessary to restore pressure-retaining items to a safe and satisfactory operating condition.

Re-ending — A method used to join original code of construction piping or tubing with replacement piping or tubing material for the purpose of restoring a required dimension, configuration or pressure-retaining capacity.

Re-rating — See alteration.

“R” Cei
possessi
rization

Safety I
a press
opening
tion to tl
pressure

Setting
require
during c
tenance

Shop —
is show
from wh
repair a
items.

Testing |
laborate
ity test

Transier
only for
state co

Velocity
that occ
of a pre
of the p
the sam
ing fluid

“VR” C
possessi
rization

Water I
must be
of test n
psi per
tracted)
the gag
the pres

[Insert new description of “Pneumatic Test.”]

Pneumatic Test — A pressure test which uses air or another compressible gas as the test medium.

[Replace existing “Pressure Test” with following text and “Note.”]

Pressure Test — An examination that is conducted using an external source of pressure to pressurize a fluid (liquid or gas) contained inside a pressure retaining item. The PRI is visually examined for signs of leakage during the application of pressure. A pressure test can be used to aid in the determination of the pressure boundary integrity of a pressure retaining item.

The NBIC recognizes two types of pressure tests; hydrostatic and pneumatic.

Note: The term “ pressure test” is sometime used to mean an operational test of a pressure relief device’s pressure relieving set point and operating parameter. The above definition does not apply PRD operational testing.

02/02