



THE NATIONAL BOARD
OF BOILER AND PRESSURE VESSEL INSPECTORS

NATIONAL BOARD INSPECTION CODE SUBGROUP PRESSURE RELIEF DEVICES

MINUTES

Meeting of January 10th, 2022
Charleston, SC

These minutes are subject to approval and are for the committee use only. They are not to be duplicated or quoted for other than committee use.

The National Board of Boiler & Pressure Vessel Inspectors
1055 Crupper Avenue
Columbus, Ohio 43229-1183
Phone: (614)888-8320
FAX: (614)847-1828

1. Call to Order

The meeting was called to order at 8:05 AM on Tuesday January 10, 2021 by Chair Kim Beise. Members and Visitors in attendance can be found on the attendance sheet (Attachments Page 1).

2. Announcements

- The National Board will be hosting a reception on Wednesday evening from 5:30pm to 7:30pm in the Colonial Ballroom.
- The National Board will be hosting breakfast and lunch on Thursday. Breakfast will be served from 7:00am to 8:00am, and lunch will be served from 11:30am to 12:30pm. Both meals will be served at the hotel in the Colonial Ballroom.
- Mr. Beirne noted that Mr. Robert Viers will be taking over secretarial duties starting with the July meeting.

3. Adoption of the Agenda

The agenda dated January 10, 2023 was presented. A motion was made and seconded to adopt the agenda. A vote was taken and the motion was unanimously approved.

4. Approval of Minutes from the July 12th, 2022 Meeting

A motion was made and seconded and seconded to approve the July 2022 minutes. A vote was taken and the motion was unanimously approved.

5. Review of the Roster ([Attachments Page 1](#))

a. Nominations

- i. None

b. Reappointments

- i. Alton Cox, Denis DeMichael, David McHugh, Brandon Nutter, Thakor Patel, Adam Renaldo, Delton Schirmer, and Jon Wolf memberships are set to expire prior to the January 2023 meeting. Their reappointment is on the SC-PRD agenda to be voted on for action.

c. Resignations

- i. Robert Donaldson and Raymond McCaffrey indicated that they will be resigning from both Subgroup and Subcommittee PRD following this meeting.

6. Interpretation Requests

Item Number: 22-36	NBIC Location: Part 4, 4.2.2	See attachments pages 2-5
General Description: Use of Code Case 2787		
Task Group: None		
January 2023 Meeting Action: The proposed interpretation request was presented. A motion was made and seconded to accept the proposed question and reply. After discussion a vote was taken. The motion passed with 12 affirmative votes, 2 negative votes (Creaser and Cox), and 3 abstentions (Patel, Donalson, DeMichael). Mr. Creaser did not like wording. Mr. DeMichael wanted more time to review the proposal. Other reasons for negatives and abstentions can be found in the attachments.		

7. Action Items

Item Number: NB15-0305	NBIC Location: Part 4	No Attachment
General Description: Create Guidelines for Installation of Overpressure Protection by System Design.		
Task Group: B. Nutter, A. Renaldo, D. Marek (PM), D. DeMichael, J. Wolf, D. Schirmer		
January 2023 Meeting Action: A revised proposal incorporating comments from the previous letter ballot was presented as a progress report. This will be letter balloted to Subgroups Installation, Inspection, and PRD between meetings.		

Item Number: NB15-0307	NBIC Location: Part 4	No Attachment
General Description: Create Guidelines for Repair of Pin Devices.		
Task Group: D. McHugh (PM), A. Renaldo, T. Tarbay, R. McCaffrey, Jay Simms, C. Bear, C. Chernisky		
January 2023 Meeting Action: This item will be letter balloted to Subgroup PRD between meetings.		

Item Number: NB15-0315	NBIC Location: Part 4, 2.5.6 and 2.6.6 and Part 1, 4.5.6 and 5.3.6	No Attachment
General Description: Review isolation Valve Requirements, and reword to allow installation of pressure relief devices in upstream piping.		
Task Group: D. DeMichael (PM), B. Nutter, A. Renaldo, D. Marek		
January 2023 Meeting Action: Work continues on this item. Part 4 text complete, will need to work on Part 1 text. Possible letter ballot to SG between meetings.		

Item Number: 19-83	NBIC Location: Part 4, Part 1	No attachment
<p>General Description: Address alternate pressure relief valve mounting permitted by ASME CC2887-1.</p> <p>Task Group: D. Marek (PM), T. Patel, J. Ball</p> <p>January 2023 Meeting Action: A revised proposal incorporating comments from the previous letter ballot was presented as a progress report. This will be letter balloted to Subgroups Installation, Inspection, and PRD between meetings.</p>		

Item Number: 20-85	NBIC Location: Part 4, 3.2.6, Part 2 2.5.8	No attachment
<p>General Description: Add language to Part 4, 3.2.6 to define test intervals for thermal fluid heaters for PRD's</p> <p>Subgroup: PRD</p> <p>Task Group: B. Nutter (PM), T. Patel, D. Schirmer, J. Wolf</p> <p>Explanation of Need: Need to align Part 4 language with work done under Item 19-88.</p> <p>January 2023 Meeting Action: This item will be letter balloted to SG Inspection and PRD between meetings.</p>		

Item Number: 21-08	NBIC Location: Part 4, S4.4	No attachment
<p>General Description: Additional guidance for tank vent repairs</p> <p>Subgroup: PRD</p> <p>Task Group: D. DeMichael (PM), H. Cornett, B. Nutter, K. Beise, J. Grace</p> <p>Explanation of Need: The recently approved S4.4, "Weight Loaded Vents," (NB12-0901) provided new guidance for tank vent repairs. Several additional topics need to be addressed to enhance the guidance. These topics include: 1) Suggested test equipment and configuration for the prescribed tank vent testing. 2) Minimum requirements for replacement parts, 3) Guidance for painting tank vent components.</p> <p>January 2023 Meeting Action: Work continues on this item.</p>		

Item Number: 21-18	NBIC Location: Part 4, 4.6.4	See attachments page 6
General Description: Pressure tests for pressure relief valve parts.		
Subgroup: PRD		
Task Group: J. Simms (PM), T. Tarbay, A. Donaldson, D. DeMichael, T. Patel, B. Nutter		
Explanation of Need: Pressure relief valve manufacturers must produce valve parts that comply with ASME Code requirements to be able to apply the ASME Symbol Stamp and Designator to a new valve. These parts are the same that are sold as repair parts. The logistic issues to fabricate and maintain an inventory of spare parts not complying with ASME Code requirements is significant versus producing all parts in compliance with code. Consequently, why have a pressure test requirement for parts purchased from the valve manufacturer for those certificate holders who chose to buy parts produced by the manufacturer?		
January 2023 Meeting Action: A motion was made and seconded to accept the attached proposal. After discussion a vote was taken and the motion passed unanimously.		

Item Number: 21-36	NBIC Location: Part 4, 3.3.3.4 i)	No Attachment
General Description: Add Test Details to NBIC Part 4, 3.3.3.4 i) Valve Adjustment and Sealing		
Subgroup: PRD		
Task Group: D. Marek (PM), A. Cox, P. Dhobi, T. Patel		
Explanation of Need: There is no reference in the T/O requirements for Set Pressure Testing, use of proper Test Fluid or Seat Tightness unless and until a minor adjustment is required. This is surely the intent, but it is not clearly specified as it is in the current VR requirements.		
January 2023 Meeting Action: Work continues on this item.		

Item Number: 21-59	NBIC Location: Part 4, 3.2.6, Part 2, 2.5.8	See attachments page 7
General Description: Deferral of inspection due dates (pressure relieving devices NBIC PART IV)		
Subgroup: PRD		
Task Group: T. Beirne (PM)		
<p>Explanation of Need: Since the code has clearly recommended inspection frequency intervals for the different classes of pressure relief devices, it shall have the requirements related to the deferral of due dates. The inspection due date deferrals are usually not considered but in exceptional cases where operating plant may not be able to handover the device due to some practical limitations or the turnaround frequency of the plant is extended due to stakeholders' requirements etc. The owner is usually ensuring that a deferment is not posing any significant EHSS risk by proper risk analysis but a clarity from code on the minimum or maximum duration the device can be deferred will add a great value in decision making. There are some codes which have added deferment clauses such as API 510 but the NBIC is always having precedence in this subject and shall have statement added to its code.</p>		
<p>January 2023 Meeting Action: A motion was made and seconded to accept the proposal that was presented. After discussion a vote was taken and the motion unanimously passed. However, after the meeting adjourned Subcommittee Inspection was presented with this proposal and had comments that require revision. The proposal will be revised and letter balloted between meetings.</p>		

Item Number: 21-61	NBIC Location: Part 4, 3.3.4	No Attachment
General Description: Audit Requirements for the T/O holder		
Subgroup: PRD		
Task Group: A. Donaldson (PM), A. Cox, J. Simms, P. Dhobi, T. Tarbay, D. Marek		
<p>Explanation of Need: Opened as a result of a Subgroup PRD ballot comment from item 21-05 (Shop audits for VR certificate holders). The comment recommended adding requirements specifically for organizations that are T/O only.</p>		
<p>January 2023 Meeting Action: This item will be letter balloted to SG PRD between meetings</p>		

Item Number: 21-62	NBIC Location: Part 4, 4.8.5.4 i 3)	See attachments page 8-11
General Description: Verification of existing spring during repair activities		
Task Group: A. Donaldson (PM), B. Nutter, E. Creaser, P. Dhobi, T. Patel, J. Simms, J. Grace, D. Gonzales, T. Cardy		
Explanation of Need: This requirement has created an administrative requirement that potentially prevents a VR Stamp holder from applying the "VR" stamp to valves they have repaired. The requirement is negatively impacting owners, and jurisdictions that enforce the NBIC Part 4. This clause introduces a unique requirement in the BPV industry to confirm that code material in a Code stamped item be verified and traceable at all time after the item is ASME code stamped but the verification can only be provided by the manufacturer. Historically, any valve received or worked on that was sealed by a VR Stamp holder or in the case of an initial repair the ASME assembler was deemed to be Code compliant, and no further verification was needed recognizing the validity and continuity of the ASME and VR quality programs. It is clearly understood that if a spring, or any other critical part is deemed necessary to be replaced during a repair the manufactures verification is required and justifiable.		
January 2023 Meeting Action: A motion was made and seconded to accept the attached proposal. After discussion a vote was taken and the motion passed with 13 affirmative votes and 4 negative votes (Creaser, Dhobi, Cox, Simms). Mr. Creaser did not like the wording other negative reasoning attached.		

Item Number: 22-08	NBIC Location: Part 4, 2.4.1.6 & 2.4.4.2; Part 1, 3.9.1.6 & 3.9.4.2	No Attachment
General Description: Review and improve guidance for T&P valve installation relating to probe.		
Subgroup: PRD		
Task Group: D. Marek (PM), J. Ball, J. Wolf, T. Clark		
Explanation of Need: Existing text refers to location of valve connection and does not give guidance that the temperature probe needs to be located in the hottest water in the tank for the valve to actuate at the specified temperature.		
January 2023 Meeting Action: Work continues on this item		

Item Number: 22-09	NBIC Location: Part 4, 4.6.1	No Attachment
General Description: Add language to NBIC Part for valves manufactured to Code Case 2787		
Subgroup: PRD		
Task Group: A. Donaldson (PM), R. Donalson, B. Nutter, T. Tarbay, J. Simms		
Explanation of Need: There are no requirements to address valve repairs that were manufactured or assembled to Code Case 2787 (use of more than one certified capacity on the pressure relief valve or the nameplate).		
January 2023 Meeting Action: Work continues on this item		

Item Number: 22-15	NBIC Location: Part 4, 2.4.5 and Part 1, 3.9.5	No Attachment
<p>General Description: What is the meaning of "service limitations" as used in Part 4, 2.4.5?</p> <p>Subgroup: PRD</p> <p>Task Group: T. Beirne (PM), B. Nutter, T. Clark</p> <p>Explanation of Need: Part 4, 2.4.5 (also Part 1, 3.9.5) references "service limitations set forth in Part 1, 3.2, Definitions" when establishing pressure relief requirements for tanks and heat exchangers. Part 1, 3.2 points readers to the glossary. As "service limitations" is not itself defined within the glossary, and the term does not appear elsewhere in the code, what specific service limitations are being referenced?</p> <p>January 2023 Meeting Action: This item will be letter balloted to Subgroups Installation and PRD between meetings</p>		

Item Number: 22-16	NBIC Location: Part 4, 2.4.4 and Part 1, 3.9.4	No Attachment
<p>General Description: Allow the use of pressure relief valves on potable water heaters.</p> <p>Subgroup: PRD</p> <p>Task Group: D. Sullivan (PM), J. Ball, T. Clark</p> <p>Explanation of Need: ASME Section IV, Part HLW-800.1 allows the use of pressure relief valves in place of temperature and pressure relief valves on potable water heaters. NBIC Parts 1 and 4 specifically require temperature and pressure relief valves, which is not consistent with the code of construction. Some manufacturers are shipping HLW stamped potable water heaters with pressure relief valves. Often the physical construction of these units is such that a temperature and pressure relief valve cannot be accommodated.</p> <p>January 2023 Meeting Action: This item will be letter balloted to Subgroups Installation and PRD between meetings</p>		

Item Number: 22-20	NBIC Location: Part 4, 4.7.4	No Attachment
<p>General Description: Inspection and testing of PRV's located above isolation valves.</p> <p>Subgroup: PRD</p> <p>Task Group: D. Marek (PM), K. Beise, J. Ball, E. Creaser, H. Cornett, A. Renaldo</p> <p>Explanation of Need: Add requirement to make sure the internals of a PRV inlet and outlet are inspected when it is tested, and require tests to be done with a pressure vessel with volume.</p> <p>January 2023 Meeting Action: Work continues on this item.</p>		

8. New Business

Item Number: 22-34	NBIC Location: Part 4, S6.3 & S6.5	Attachment pages 12
General Description: Update duplicate nameplate marking requirements in Supplement 6		
Subgroup: PRD		
Task Group: None assigned.		
Explanation of Need: With the publication of Section XIII updates to the duplicate nameplate requirements were needed to refer to designator rather than code section. This item will also make the marking requirements consistent with those in the pending publication of updated paragraph 4.7.4 resulting from item 21-84.		
January 2023 Meeting Action: A motion was made and seconded to accept the attached proposal. After discussion a vote was taken and the motion passed unanimously.		

Item Number: 22-35	NBIC Location: Part 4, 4.6.2	Attachment pages 13
General Description: Update reference of Section VIII steam valves to UV designated steam valves		
Subgroup: PRD		
Task Group: None assigned.		
Explanation of Need: With the publication of Section XIII new UV designated valves are constructed to Section XIII. The references should be to UV designator not code section.		
January 2023 Meeting Action: A motion was made and seconded to accept the attached proposal. After discussion a vote was taken and the motion passed unanimously.		

9. Presentations

None

10. Future Meetings

- July 2023 – St. Louis, MO
- January 2024 – Charlotte, NC

11. Adjournment

The meeting was adjourned at 3:10 PM.

Respectfully Submitted,

Thomas P. Beirne, P.E.
Secretary, NBIC Subgroup Pressure Relief Devices
pc: J. Amato
G. Galanes
J. Ellis

Subgroup PRD Attendance - January 10, 2022

MEMBERS:	Interest Category	In Person	Remote	Not In Attendance
Kim Beise - Chair	National Board Certificate Holders		X	
Daniel Marek - Vice Chair	General Interest		X	
Thomas Beirne - Secretary		X		
J. Alton Cox	General Interest	X		
Eben Creaser	Jurisdiction	X		
Denis DeMichael	Users		X	
Prakash Dhobi	National Board Certificate Holders	X		
Alfred Donaldson	Manufacturers		X	
Robert Donaldson	Manufacturers	X		
Raymond McCaffrey	General Interest			X
David McHugh	National Board Certificate Holders	X		
Brandon Nutter	National Board Certificate Holders		X	
Thakor Patel	Manufacturers		X	
Adam Renaldo	Users	X		
Delton Schirmer	Authorized Inspection Agencies	X		
Jay Simms	Manufacturers	X		
David Sullivan	Jurisdiction	X		
Thomas Tarbay	General Interest	X		
Jon Wolf	Authorized Inspection Agencies	X		

VISITORS:	Company/Title/Interest	In Person	Remote
Luis Ponce	NBBI	X	
Gary Scribner	NBBI	X	
Clark Turner	Calder	X	
Jeremy Grace	Chemours	X	
Hank Cornett	Emerson Automation Solutions	X	
Craig Theiler	Law Valve of Texas	X	
Ray Ceccarelli	FM Global	X	
Kim Black	ABMA	X	
Bob Viers	NBBI	X	



PROPOSED INTERPRETATION

Item No. 22-36
Subject/Title Use of Code case 2787 in Repairs
Project Manager and Task Group
Source (Name/Email) Alfred Donaldson / alfred.donaldson@bakerhughes.com
Statement of Need Code Case 2787 was approved by ASME to allow a manufacturer to develop valves that will work on multimedia applications without any required adjustments. These valves may have different components and will have multiple certified capacities. As these valves are entering the marketplace, some customers are requesting that their existing valves get converted to the multimedia type valves. This request would allow the NBIC Committee to adopt the Code Case for us in the VR program in accordance with NBIC Part 4.2.2 and allow the VR holder to convert a valve to a multimedia design that has more than one certified capacity on the valve nameplate.
Background Information This is a Part 4 issue but the system only shows Part 1 & 2
Proposed Question Under the provisions of paragraph 4.2.2, is it permissible to apply Code Case 2787 and convert a pressure relief valve by adding more than one certified capacity on the pressure relief valve or nameplate?
Proposed Reply Proposed Reply: Yes, provided that the "VR" Certificate Holder verifies that: 1. All of the requirements of ASME Code Case 278 are met, and 2. That all of the requirements of the NBIC concerning conversions, and specifically paragraph 4.7.3 are met.
Committee's Question 1
Committee's Reply 1
Rationale
Committee's Question 2
Committee's Reply 2
Rationale

Tom Beirne

From: Alton Cox <alton@jaltoncox.com>
Sent: Tuesday, January 10, 2023 9:48 AM
To: Tom Beirne
Cc: Bob Viers
Subject: ITEM 22-36

Tom:

Regarding NBIC Part 4, SG-PRD, Item 22-36, for interpretation of ASME Code Case 2787 for use in VR Conversions, my negative is based on the following issues:

- 1) I understand the intent, but I do not agree with the wording, "Provision to include all the requirements of the Code Case." "All" appears to require Capacity Testing by the VR Holder.
- 2) Ambiguity of the second sentence of the explanation, "*These valves may have different components and will have multiple certified capacities.*" This sounds like there may be parts changes required for specific fluids, but retesting is NOT required. I don't see how that can be multi-media.
- 3) Third sentence appears to say "us," but the content infers "use." Needs editing.
- 4) Proposed reply should read Code case 2787 rather than 278.

Thank you for the opportunity to express my concerns.

Regards,
Alton Cox

Interpretation Request Item 22-36

Use of Code Case 2787 in repairs

NBIC SG Pressure Relief Device

I am abstaining from voting on this item as I am concerned, we have not provided enough clarification on how this interpretation would be implemented. The reference paragraphs in the Code Case have changed, the reference to the code case nameplate is not clear, no guidance for listing the multiple capacities on the repair nameplate, no guidance on what nameplate the code case number should appear as part of the conversion.

In my opinion this interpretation should be limited to repairs of pressure relief valves which currently bear the code case number only. To extend this interpretation to say cover conversions of pressure relief valves that were not originally manufactured/assembled to Code Case 2787 should be addressed under the current open Item #22-09 "add language to NBIC Part 4 for valves manufactured to Code Case 2787.

Bob Donalson

Tom Beirne

From: Thakor Patel <thakorpatel1@gmail.com>
Sent: Tuesday, January 10, 2023 9:59 PM
To: Tom Beirne
Subject: Interpretation #22-36

Tom,

I abstained from voting for the interpretation #22-36, use of code case 2787 in repairs for the following reason.

Paragraph 4.2.2 states that ASME code cases shall be used for repairs when they were used in the original code of construction of the valve. The proposed interpretation covers for the valve where code case 2787 is not used, but it does not cover for the valve where the code case is used in original construction and converted into a regular type of valve. Also VR shops may not have the instruction or experience for converting the valves into 2787 code case valves where multiple capacities are marked on the nameplate.

Regards,

Thakor Patel

ITEM 21-18 Proposal 1/10/23

4.6.4 PRESSURE TEST OF PARTS

- a) Parts used in repaired valves, that are required to be pressure tested by the original code of construction, shall be pressure tested and documentation provided according to the following categories:

1) Replacement Parts

The "VR" Certificate Holder is responsible for documentation that the appropriate pressure test has been completed ~~as required by the original code of construction~~.

2) Parts Repaired by Welding

These parts shall be subjected to at the required pressure test ~~required by the original code of construction~~. The "VR" Certificate Holder shall be responsible for documentation of such test.

- b) Parts repaired by re-machining within part specification, lapping, or polishing do not require a pressure test.

ITEM 21-59 Proposal 1/10/23

NBIC Part 4

3.2.6 RECOMMENDED INSPECTION AND TEST FREQUENCIES FOR PRESSURE RELIEF DEVICES

Frequency of test and inspection of pressure relief devices is greatly dependent on the service, external environment, and operation of the system, therefore only general recommendations can be given. Inspection frequency should be based on previous inspection history and/or manufacturer's recommendations. Where the Jurisdiction has adopted other Standards for specific applications, those Standards may be used. If, during inspection, valves are found to be defective or damaged, intervals should be shortened until acceptable inspection results are obtained. Where test records and/or inspection history are not available, the following inspection and test frequencies are suggested:

NBIC Part 2

2.5.8 RECOMMENDED INSPECTION AND TEST FREQUENCIES FOR PRESSURE RELIEF DEVICES

Frequency of test and inspection of pressure relief devices is greatly dependent on the service, external environment, and operation of the system, therefore only general recommendations can be given. Inspection frequency should be based on previous inspection history and/or manufacturer's recommendations. Where the Jurisdiction has adopted other Standards for specific applications, those Standards may be used. If, during inspection, valves are found to be defective or damaged, intervals should be shortened until acceptable inspection results are obtained. Where test records and/or inspection history are not available, the following inspection and test frequencies are suggested:

i) Repair and Inspection Program

The repair and inspection program section shall include reference to a document (such as a report, traveler, or checklist) that outlines the specific repair and inspection procedures used in the repair of pressure relief valves. Repair procedures shall require verification that the critical parts meet the valve manufacturer's specification. Supplement 4 outlines recommended procedures covering some specific items. This document shall be retained in accordance with Table 4.8.5.4 s).

- 1) Each valve or group of valves shall be accompanied by the document referred to above for processing through the plant. Each valve shall have a unique identifier (i.e., repair serial number, shop order number, etc.) appearing on the repair documentation and repair nameplate such that traceability is established.
- 2) The document referred to above shall describe the original nameplate information, including the ASME Code symbol stamping and the repair nameplate information, if applicable. In addition, it shall include material checks, replacement parts, conversion parts (or both), reference to items such as the welding procedure specifications (WPS), fitup, NDE technique, heat treatment, and pressure test methods to be used. Application of the "VR" stamp to the repair nameplate shall be recorded in this document. Specific conversions performed with the new Type/Model number shall be recorded on the document. There shall be a space for "signoffs" at each operation to verify that each step has been properly performed.
- 3) The system shall include a method of controlling the repair or replacement of critical valve parts. The method of identifying each spring shall be indicated on the repair document described in 4.8.5.4 i). Such identification shall be based on the Manufacturer's spring chart current at the time of the repair, except that the spring removed from the valve during the repair bearing different identification may be reinstalled provided the "VR" Certificate Holder has verified the spring is acceptable to the Manufacturer. Such verification shall be documented on the repair document described in 4.8.5.4 i).
 - a. If such verification is not possible, the "VR" Certificate Holder may reinstall the existing spring with acceptance from the Jurisdiction. Such acceptance shall be documented on the repair document described in 4.8.5.4 i).

Tom Beirne

From: Dhobi, Prakash <Prakash.Dhobi@lakesidecontrols.com>
Sent: Tuesday, January 10, 2023 3:55 PM
To: Tom Beirne; Bob Viers
Subject: Re: Item 21-62

Dear Tom and Bob,

I am formally written to the SG committee on why I am voting abstain. We as a Task group did not had a chance to review as a group and come to concession on what was discussed today.

The path forward should be collective reviewed before presentation to ensure we are presenting the information.

Item Number: 21-62	NBIC Location: Part 4, 4.8.5.4 i) 3)	No Attachment
General Description: Verification of existing spring during repair activities		
Task Group: A. Donaldson (PM), B. Nutter, E. Creaser, P. Dhobi, T. Patel, J. Simms, J. Grace, D. Gonzales, T. Cardy		
Explanation of Need: This requirement has created an administrative requirement that potentially prevents a VR Stamp holder from applying the "VR" stamp to valves they have repaired. The requirement is negatively impacting owners, and jurisdictions that enforce the NBIC Part 4. This clause introduces a unique requirement in the BPV industry to confirm that code material in a Code stamped item be verified and traceable at all time after the item is ASME code stamped but the verification can only be provided by the manufacturer. Historically, any valve received or worked on that was sealed by a VR Stamp holder or in the case of an initial repair the ASME assembler was deemed to be Code compliant, and no further verification was needed recognizing the validity and continuity of the ASME and VR quality programs. It is clearly understood that if a spring, or any other critical part is deemed necessary to be replaced during a repair the manufactures verification is required and justifiable.		
July 2022 Meeting Action: Work continues on this item.		

If such verification is not possible the VR cert holder may reinstall the existing spring with acceptance from the jurisdiction. Such approval shall be documented on the repair document on the repair document describe in 4.8.5.4i

Prakash Dhobi, A.Sc.T | Mechanical Services Lead
 Lakeside Process Controls Ltd. | 63 Innovation Dr | Hamilton | ON | L9H 7L8
 A Member of the Emerson Impact Partner Network
 T: 1.289.919.3508 | C: 1.226.979.2965
 Prakash.Dhobi@lakesidecontrols.com | www.lakesidecontrols.com
 Follow us on [LinkedIn](#)

Help us **improve your experience** by sharing your thoughts in our quick survey | [GIVE FEEDBACK](#)

COVID-19 Update: Please visit [here](#) to see the measures we have implemented to remain safe, while continuing to serve the needs of our customers.

Tom Beirne

From: Simms, Jack <Jack.Simms@bakerhughes.com>
Sent: Thursday, January 12, 2023 9:58 AM
To: Tom Beirne; Bob Viers
Subject: Negative Vote on Item 21-62

Tom,

As always, thank you for your leadership and guidance. With regard to Item 21-62, and the negative vote that I cast, please see the following.

- I do not have an issue with the verbiage proposed regarding the authority of the Jurisdiction to act in approval when needed
- I do not have an issue with the existing requirement for verification due to changes over time in design and deflection
- I do not believe the impact on the industry (proven by the continued and contentious discussion) can be overstated when we implement a requirement without provision of the necessary data to meet the conditions of the requirement
- I do not believe that the proposal offered in SG/SC was properly vetted – even at the Task Group level
- I do not believe that it is in the best interest, for safety of the industry and all personnel, that we patch and proceed this issue until we've exhausted all possible opportunities that we may have as a committee

For these reasons, I voted against Item 21-62 in both SG and SC PRD.

Sincerely,

Jay Simms
Consolidated Pressure Relief Valves
Senior Sales Manager
M +1 225 305 7315
Email: Jack.Simms@BakerHughes.com

[Consolidated LinkedIn](#)
[valves.bakerhughes.com](https://www.valves.bakerhughes.com)

Consolidated
a Baker Hughes business

Tom Beirne

From: Alton Cox <alton@jaltoncox.com>
Sent: Monday, January 30, 2023 10:53 AM
To: Tom Beirne
Subject: Re: NBIC Item 21-62 negative

Tom:

Regarding my negative for Item NBIC Item 21-62, my concern is the NBIC requirement for Inspection of Critical Parts in a PRV.

- 1) Everyone on the SC-PRD should agree the PRV Spring is a Critical Part per NBIC Part 4, Sec. 4.3.1 a).
- 2) Per NBIC Part 4, Sec. 4.8.5.4 g), g) Drawings and Specification Control
 - a. *"The drawings and specification control system shall provide procedures assuring that the latest applicable drawings, specifications, and instructions required are used for valve repair, including conversions, inspection, and testing."*
 - b. **NOTE: These words were in NBIC long before "current at the time of the repair" was added.**
- 3) Finally, the inquirer's "Explanation of Need," states, *"It is clearly understood that if a spring, or any other critical part is deemed necessary to be replaced during a repair the manufactures verification is required and justifiable."*

Based on the above, I voted negative on this item because the requirement for identification of the PRV needs to be based on the Manufacturer's Specifications in accordance with the NBIC. The Manufacturer determines the necessary spring for a particular PRV design, orifice and set pressure. No other source of Spring Identification makes sense from an engineering or safety perspective.

Thank you for the opportunity to comment.

Regards,
Alton Cox
JAC Consulting, Inc.

ITEM 22-34 12/1/22**S6.3 NUCLEAR SAFETY RELATED VALVE GROUPS**

These rules classify nuclear safety related pressure relief valves into three groups based upon the original code of construction and capacity certification status.

Group 1: ASME ~~Section I and Section VIII~~ "V" and "UV" designated pressure relief valves accepted by the Jurisdiction for use in nuclear safety related service with National Board capacity certification.

Group 2: ASME ~~Section III~~ "NV" stamped-designated Class 1, 2, or 3 pressure relief valves with National Board capacity certification.

Group 3: Pressure relief valves not addressed in Group 1 or Group 2. This group shall include pressure relief valves without National Board capacity certification and/or pressure relief valves constructed to codes or standards other than ASME (see NBIC Part 3, Category 3).

The term pressure relief valve includes power actuated pressure relief valves. Replacement of rupture disks in rupture disk holders or in systems is not considered a repair activity under the scope of this supplement.

S6.5 GENERAL RULES

e) When an ASME "V", "UV" or "NV" stamped-designated pressure relief device requires a duplicate nameplate because the original nameplate is illegible or missing, it may be applied using the procedures of NBIC Part 4, 4.7.4 provided concurrence is obtained from the Authorized Nuclear Inspector and Jurisdiction. In this case the nameplate shall be marked "~~SEC.-IV~~", "~~SEC.-IIIN~~V", or "~~SEC.-VIII~~UV" to indicate original ASME Code stamping or designator.

ITEM 22-35 1/10/23

4.6.2 OWNER-USER ~~ASME CODE SECTION VIII STEAM TESTING~~ OF ASME “UV” DESIGNATED STEAM SERVICE VALVES

When ASME ~~Code Section VIII~~ “UV” designated valves are repaired by the owner for the owner’s own use, valves for steam service may be tested on air for set pressure and, if possible, blowdown adjustment, provided the valve manufacturer’s corrections for differential in set pressure between steam and air are applied to determine the test pressure as follows:

Staff editorial note: Table of Contents will need to be updated